Amended 4/10/2024

STATE OF OREGON

ABANDONMENT WELL REPORT

WELL I.D. LABEL# L	151844	
START CARD#		

(as required by ORS 537.765, OAR 690-205-0210 & OAR690-240-0395)	I ANE 70460
(1) LAND OWNER Owner Well I.D.	(6) LOCATION OF WELL (legal description) LANE 79469
First Name THOMAS Last Name MORLEY	County LANE Twp 19 S N/S Range 12 W E/W WM
Address 85020 HWY 101	Sec <u>3</u> SE 1/4 of the <u>SE</u> 1/4 Tax Lot <u>5400</u>
City FLORENCE State OR Zip 97439	Tax Map Number Lot
(2) TYPE OF WELL water supply	Lat <u>43.943513</u> or DD or DMS Long <u>124.104376</u> or DD or DMS
ORIGINAL LOG # LANE 2164	Street address of well Nearest address
(3) EXISTING CONDITIONS (not required if well report identified in (2) describes the well's current condition)	85020 HWY 101, FLORENCE, OREGON 97439
Depth of well: 110 ft.	(7) STATIC WATER LEVEL Date Above SWL(ft) SWL(psi)
Filter pack from ft. to ft. Material Size	Existing Well/Pre-Abandonment 10-03-2023 64
	(9) DESCRIPTION OF ARANDONMENT CC
Above To Screen Other Material	Ground Elevation
	Was not able to pull screen or casing. Installed trimmie to 110 ft and pressure grouted from the bottom of well to land surface.
(4) ABANDONMENT PROCEDURE Special Standard (Attach copy)	
Size Perfs # Perf Other Info	RECEIVED MAR 25 2024 OWRD
Bentonite Chips 6 0 5 2 S 1.42	
Cement 6 5 110 23 S 17.57	
	Date Started 10-04-2023 Completed 10-07-2023
	(unbonded) Water Well Constructor Certification
	I certify that the work I performed on the construction, deepening, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief. License Number Date
	Signed
	(bonded) Water Well Constructor Certification
Calculate Required Amounts If you're using Adobe, the button above will calculate required amounts based on what you enter on pp. 1-2 Actual Cement: 23 Sacks 0 lbs. Actual Bentonite: 2 Sacks 0 lts. Calculated Cement: 17.57 Sacks 0 lbs. Calculated Bentonite: 1.42 Sacks 0 lts. Total Dissolved Solids Temperature F	I accept responsibility for the construction, deepening, alteration, or abandonmen work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.
(5a) ABANDONMENT USING UNHYDRATED BENTONITE	Contact Info (optional)
Proposed Amount Sacks Actual Amount Sacks	