NOTICE TO WATER WELL CONTRACTOR

WATER WELL REPORT

Estate Permit No.

The original and first copy
of this report are to be
filed with the
STATE OF OREGON
within 30 days from the date
of well completion.

WATER WELL REPO

STATE WELL REPO

WATER WELL REPO

STATE OF OREGON
(Please type or print)

(1) OWNER: Name Paul Bishop	(11) WELL TESTS: Drawdown is amount water lowered below static level Was a pump test made? Yes Drawdown is amount water lowered below static level No If yes, by whom?	level is
Address 380 Bishop Lane	Yield: 220 gal./min. with 17 ft. drawdown after	er 2 hrs.
Junction City, Oregon	n n	***
(2) LOCATION OF WELL:	11 21	***
County Lane Driller's well number	Bailer test gal./min. with ft. drawdown aft	ter hrs.
1/4 1/4 Section 22 T. 16S R. X 4W W.M.	Artesian flow g.p.m. Date	
Bearing and distance from section or subdivision corner	Temperature of water Was a chemical analysis made?	☐ Yes ☐ No
	(12) WELL LOG: Diameter of well below casing	8
	Depth drilled 44 ft. Depth of completed well 4	_
	Formation: Describe by color, character, size of material and show thickness of aquifers and the kind and nature of the m stratum penetrated, with at least one entry for each change	
	MATERIAL FRO	ом то
(3) TYPE OF WORK (check):	Top Soil 0	4
New Well Deepening ☐ Reconditioning ☐ Abandon ☐	Sand & Gravel, Heavy clay 4	25
bandonment, describe material and procedure in Item 12.	Sand & Gravel, Slight Clay, 25	44
(4) PROPOSED TISE (-11-). (F) TEXTRE OF WELL I	small cobbles	
(4) PROPOSED USE (check): (5) TYPE OF WELL:		
Domestic ☐ Industrial ☐ Municipal ☐ Rotary ☐ Driven ☐ Cable ☑ Jetted ☐		
Irrigation Test Well Other Dug Bored		
(6) CASING INSTALLED: Threaded □ Welded □		
	——————————————————————————————————————	
"Diam. fromft. Gage		
(7) PERFORATIONS: Perforated? ★Yes □ No		
Type of perforator used Torch		
Size of perforations 3/8 in. by 4 in.		
perforations fromft. toft.		
Torch perforations from24 ft. to44 ft.		
perforations from		
perforations from ft. to ft.		
perforations from ft. to ft.		
(8) SCREENS: Well screen installed ☐ Yes ☑ No		
Manufacturer's Name		
eModel No		
Stam. Slot size Set from ft. to ft.	Work started 2/12 19 62 Completed 2/21	¹⁹ 62
Diam Slot size Set from ft. to ft.	Date well drilling machine moved off of well	19
(9) CONSTRUCTION:	(13) PUMP:	
Well seal—Material used in seal	Manufacturer's Name	
Depth of seal ft. Was a packer used?	Type: H.P.	
Diameter of well bore to bottom of seal in.	Water Well Contractor's Certification:	
Were any loose strata cemented off? ☐ Yes ☐ No Depth	1	
Was a drive shoe used? Yes No	This well was drilled under my jurisdiction and the true to the best of my knowledge and belief.	als report is
Was well gravel packed? Yes No Size of gravel:		
Gravel placed from ft. to ft.	NAME CARTER'S DRILLING & PUMP SERVICE (Person, firm or corporation) (Type or print)	
Did any strata contain unusable water? Yes No	Address 325 SO. 2nd Street, Springfield, Oregon	
Type of water? Depth of strata	Ziuriess	
Method of sealing strata off Drill Sludge	Drilling Machine Operator's License No.	
(10) WATER LEVELS:		
Static level 6 ft. below land surface Date 2/21/62	[Signed] (Water Well Contractor)	
Artesian pressure lbs. per square inch Date	Contractor's License No. 126 Date 5/28/62	10