

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

MAR 24 1969

WATER WELL REPORT

STATE OF OREGON

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion

STATE ENGINEER SALEM, OREGON

(Please type or print) (Do not write above this line)

MAR 27 1969

State Well No. 16/4w-22dd

State Permit No.

(1) OWNER:

Name Orville Chapman
Address 281 Wedgewood Drive
Eugene, Oregon 97402

(2) TYPE OF WORK (check):

New Well [x] Deepening [ ] Reconditioning [ ] Abandon [ ]

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [ ] Driven [x]
Cable [ ] Jetted [ ]
Dug [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [x] Industrial [ ] Municipal [ ]
Irrigation [x] Test Well [ ] Other [ ]

CASING INSTALLED:

4" Diam. from point 21 ft. to 21 ft. Gage 237
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? [x] Yes [ ] No.
Type of perforator used 1/4" burned
Size of perforations 1/4 in. by 10 in.
1/4 x 10" perforations from point ft. to 4 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [ ] Yes [ ] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 8 ft. below land surface Date
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [x] Yes [ ] No If yes, by whom?
Yield: 250 gal./min. with ft. drawdown after hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [ ] Yes [ ] No

(10) CONSTRUCTION:

Well seal—Material used concrete
Depth of seal 6 ft.
Diameter of well bore to bottom of seal in.
Were any loose strata cemented off? [ ] Yes [ ] No Depth
Was a drive shoe used? [ ] Yes [ ] No
Did any strata contain unusable water? [ ] Yes [ ] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [ ] Yes [ ] No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Lane Driller's well number
SE 1/4 SE 1/4 Section 22 T. 16S R. 14W W.M.

Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 4
Depth drilled 21 ft. Depth of completed well 20 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows include Top Soil, Loam, Hard Pan, Sand & Gravel.

Work started 3-17-69 19 Completed 3-17-69 19

Date well drilling machine moved off of well 3-17-69 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Owen Hart Date 3-17-69, 19
(Drilling Machine Operator)

Drilling Machine Operator's License No. 140

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Miller-Jensen Company
(Person, firm or corporation) (Type or print)

Address P.O. Box 2571, Eugene, Ore 97402

[Signed] Harry A. Miller Owner
(Water Well Contractor)

Contractor's License No. 179 Date 3-19-69, 19