NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

(Do not write above this line)

LANE 869

State Well No. 16S/2E-30da

State Permit No. .....

(1) OWNER:

Name Pat Patterson

Address 91039 Angleo Flight
Vida, OR 97488

(2) TYPE OF WORK (check):

New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☑ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☑

6" Diam. from 0 ft. to 85 ft. Gage 250
..." Diam. from ... ft. to ... ft. Gage ...
..." Diam. from ... ft. to ... ft. Gage ...

(6) PERFORATIONS: Perforated? ☐ Yes ☑ No.

Type of perforator used

Size of perforations in. by in.

... perforations from ... ft. to ... ft.
... perforations from ... ft. to ... ft.
... perforations from ... ft. to ... ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No

Manufacturer's Name ...

Type ... Model No. ...

Diam. ... Slot size ... Set from ... ft. to ... ft.
Diam. ... Slot size ... Set from ... ft. to ... ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☑ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "

~~Bailer~~ Blow test 30 gal./min. with 60 ft. drawdown after 1 hrs.

Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ... ft.

(9) CONSTRUCTION:

Well seal—Material used Cement

Well sealed from land surface to 85 ft.

Diameter of well bore to bottom of seal 9 in.

Diameter of well bore below seal 6 in.

Number of sacks of cement used in well seal 24 sacks

How was cement grout placed? Mixed & pumped Bottom up

Was a drive shoe used? ☐ Yes ☑ No Plugs ... Size: location ... ft.

Did any strata contain unusable water? ☐ Yes ☑ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☑ No Size of gravel: ...

Gravel placed from ... ft. to ... ft.

(10) LOCATION OF WELL:

County Lane Driller's well number

NE ¼ SE ¼ Section 30 T. 16S R. 2E W.M.

Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 90 ft.

Static level 25 ft. below land surface. Date 8/30/79

Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6

Depth drilled 100 ft. Depth of completed well 100 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	4	
yellow clay	4	25	
Red clay	25	48	
yellow clay	48	80	
Blue Rock	80	90	
Brown Rock	90	100	35

RECEIVED
SEP 1979
WATER RESOURCES DEPT
SALEM, OREGON

Work started 8/29 1979 Completed 8/29 1979

Date well drilling machine moved off of well 8/30 1979

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Frank Wilson Date 8/30, 1979
(Drilling Machine Operator)

Drilling Machine Operator's License No. 404

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name W.W. Drilling & Pump Service
(Person, firm or corporation) (Type or print)

Address 2320 Main St. Spfd. OR 97477

[Signed] Frank Wilson
(Water Well Contractor)

Contractor's License No. 562 Date 8/30, 1979

(USE ADDITIONAL SHEETS IF NECESSARY)