

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

LANE 9101 WATER WELL REPORT

LANE
9101
NW

State Well No. 1605/LeW-32-d

WATER RESOURCES DEPARTMENT
SALEM, OREGON 97310
within 30 days from the date
of well completion.

RECEIVED

STATE OF OREGON

(Please type or print)

AUG 9 1977

(Do not write above this line)

WATER RESOURCES DEPT.

(1) OWNER: SALEM, OREGON
Name Luthern Retreat #2 (RW)
Address Poodle Creek Rd.
Veneta, Oregon

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: Rotary Cable Plug
Driven Jetted Bored
(4) PROPOSED USE (check): Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED: Threaded Welded
6" Diam. from +1 ft. to 19 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? Yes No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Driller
1: 20 gal./min. with 196 ft. drawdown after 2 hrs.
" " " " "
" " " " "
Baller test No gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 54° Depth artesian flow encountered ft.

(9) CONSTRUCTION: Well seal—Material used Portland Cement
Well sealed from land surface to 19 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 5 sacks
How was cement grout placed? Cement Grout Pump
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Lane Driller's well number 3023-CP
1/4 SE 1/4 Section 32 T. 16S R. 6W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 164 ft.
Static level 4 ft. below land surface. Date 7/30/77
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 210 ft. Depth of completed well 210 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	7	
Brown Sandstone	7	18	
Grey Sandstone	18	210	4

Work started 7/30/ 19 77 Completed 8/1/ 1977
Date well drilling machine moved off of well 8/1/ 1977

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] [Signature] Date 8/1/ 1977
(Drilling Machine Operator)
Drilling Machine Operator's License No. 717

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Carter's Drilling & Pump Service
(Person, firm or corporation) (Type or print)
Address P.O. Box 46-Springfield, Oregon 97147
[Signed] [Signature]
(Water Well Contractor)
Contractor's License No. 126 Date 8/1/ 1977