

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report  
are to be filed with the

**RECEIVED**

**WATER WELL REPORT**

WATER RESOURCES DEPARTMENT  
SALEM, OREGON 97310  
within 30 days from the date  
of well completion

DEC 7 1978

STATE OF OREGON  
(Please type or print)

LANE  
9518

State Well No. 165/35-200  
State Permit No.

WATER RESOURCES DEPT. write above this line  
SALEM, OREGON

**(1) OWNER:**

Name Nat Giustina (RW)  
Address 880 Crest Drive  
Eugene, Oregon

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
Cable  Jetted   
Dug  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**(5) CASING INSTALLED:**

Threaded  Welded   
8" Diam. from 1 ft. to 46 ft. Gage .250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

**(6) PERFORATIONS:**

Perforated?  Yes  No.

Type of perforator used  
Size of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

**(7) SCREENS:**

Well screen installed?  Yes  No

Manufacturer's Name Johnson  
Type Stainless Steel Model No. Telescope  
Diam. 8 Slot size 50 Set from 47 ft. to 67 ft.  
Diam. Slot size Set from ft. to ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?  
gal./min. with ft. drawdown after hrs.  
Bailer test 45 gal./min. with 1 ft. drawdown after 2 hrs.  
Artesian flow g.p.m.  
Temperature of water 51 Depth artesian flow encountered ft.

**(9) CONSTRUCTION:**

Well seal—Material used Portland Cement Type III  
Well sealed from land surface to 32 ft.  
Diameter of well bore to bottom of seal 12 in.  
Diameter of well bore below seal 8 in.  
Number of sacks of cement used in well seal 32 sacks  
How was cement grout placed? Pumped From Bottom Up to Top Land Surface

Was a drive shoe used?  Yes  No Plugs Size: location ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.

**(10) LOCATION OF WELL:**

County Lane Driller's well number 1423/71  
1/4 SW 1/4 Section 20 T. 16 R. 3E W.M.  
Bearing and distance from section or subdivision corner

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found 35 ft.  
Static level 28 ft. below land surface. Date 11/27/78  
Artesian pressure lbs. per square inch. Date

**(12) WELL LOG:**

Diameter of well below casing 8"  
Depth drilled 75 78 ft. Depth of completed well 78 75 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil Brown Sandy Loam	0	6	
Brown Clay / Sand & Gravel	6	25	
Brown Clay	25	35	
Smal Cobbles & Gravel	35	53	28
Sand Gravel	53	72	28
Black Sand	72	75	28

Work started 10/24/ 19 78 Completed 11/27/ 19 78  
Date well drilling machine moved off of well 11/27/ 19 78

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] James D. Carter Date 11/27/, 19 78  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 1009

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name Carter's Drilling & Pump Service  
(Person, firm or corporation) (Type or print)  
Address P.O. Box 46 Springfield, Oregon 97177  
[Signed] James D. Carter  
(Water Well Contractor)  
Contractor's License No. 126 Date 11/27/, 19 78