

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

RECEIVED
JUL 3 1 1969

WATER WELL REPORT

STATE OF OREGON

Please type or print

Do not write above this title

RECEIVED
SEP - 5 1969

STATE ENGINEER

SALEM, OREGON

State Well No.

State Permit No.

16/5-16 ac

LANE 9708

(1) OWNER:

Name TOKATEE Golf Course
Address McKinzie Bridge Oregon

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

CASING INSTALLED:

12" Diam. from +2 ft. to 191 ft. Gage 250
193" Diam. from 1 ft. to 1 ft. Gage 1

PERFORATIONS:

Perforated? ☐ Yes ☒ No.

Type of perforator used Mills Knife
Size of perforations 3/8 in. by 3 in.
300 perforations from 18' ft. to 55 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 10' 4" ft. below land surface Date 7/17/69
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom? Driller
Yield: 300 gal./min. with 21 ft. drawdown after 3 hrs.
350 " 25 (Pulling sand) 5 "
450 " 38' (55' IT) 2 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 49 Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:

Well seal—Material used Cement
Depth of seal 18 ft.
Diameter of well bore to bottom of seal 18 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☒ Yes ☐ No
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Lane Driller's well number
1/4 1/4 Section 17 T. 16S R. 5E W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 12

Depth drilled 225 ft. Depth of completed well 225 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Clay	0	10	
Clay & Boulders	10		
Sand & gravel		30	10'
gray cement brick & sand	30	40	
Water streaked			
28'			
Sand & gravel	40'	45'	10'
Cement gravel	45	65	15'
Brown sand & silt			
Very fine water			
Bedding	65	225	
To Fine To Green			

Work started 6/16 19 69 Completed 7/18 19 69

Date well drilling machine moved off of well 7/18 19 69

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] R.D. Zehn Date 7/18, 19 69
(Drilling Machine Operator)

Drilling Machine Operator's License No. 27

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME W. W. Drilling & Pump Service
(Person, firm or corporation) (Type or print)

Address 2320 Main St. Springfield, Ore.

[Signed] Watt Wilson
(Water Well Contractor)

Contractor's License No. 268 Date 7/23/69, 19 69