

The original and first copy
of this report are to be
filed with the

LANE

9709

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON
(Please type or print)

State Well No. 16/5-16ac

State Permit No.

(2) LOCATION OF WELL:

County	Lane	Driller's well number
¼	¼ Section	16 T. 16 S R. 5 E W.M.
Bearing and distance from section or subdivision corner		

(3) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
 If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary	☐	Driven	☐
Cable	☒	Jetted	☐
Dug	☐	Bored	☐

(6) CASING INSTALLED: Threaded ☐ Welded ☒
 12" Diam. from 0 ft. to 60 ft. Gage Std
 " Diam. from ft. to ft. Gage
 " Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? ☒ Yes ☐ No

Type of perforator used		Mills	
Size of perforations	in. by		in.
256	perforations from	25	ft. to 57
	perforations from		ft. to
	perforations from		ft. to
	perforations from		ft. to
	perforations from		ft. to

(8) **SCREENS:** Well screen installed? ☐ Yes ☒ No

Manufacturer's Name _____ Model No. _____

Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Puddled clay & cement

Depth of seal 21 ft. Was a packer used? Yes

Diameter of well bore to bottom of seal 16 in.

Were any loose strata cemented off? ☐ Yes ☒ No Depth

Was a drive shoe used? ☒ Yes ☐ No

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

Did any strata contain unusuable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

(10) WATER LEVELS:

Static level 26 ft. below land surface Date 10-22-64
Artesian pressure _____ lbs. per square inch Date _____

(11) **WELL TESTS:** Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☐ No If yes, by whom?

Yield:	gal./min. with	ft. drawdown after	hrs

99 99 99 99

11 11 11 11

Bailer test 400 gal./min. with 34 ft. drawdown after 1 hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(12) WELL LOG: Diameter of well below casing 12"

Depth drilled 60 ft. Depth of completed well 60 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

[illegible]

Work started 10-14-64 . . . Completed 10-22-64 19

Date well drilling machine moved off of well. 10-23-64 19

(13) PUMP:

Manufacturer's Name

Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Casey Jones Well Drilling Company
(Person, firm or corporation) (Type or print)

Address Rt. 2 Box 695 Creswell, Oregon

Drilling Machine Operator's License No. _____

[Signed] Robert S. Jones
(Water Well Contractor)

Contractor's License No. 103 Date 12-1-64 1964

(USE ADDITIONAL SHEETS IF NECESSARY)