

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

RECEIVED
FEB 17 1971
STATE ENGINEER
SALLM OREGON

STATE ENGINEER, SALEM, OREGON
within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

State Well No. 16/6-11
State Permit No. LANE 9773

(1) OWNER:

Name JIM NATION (RW)
Address BELNAP SPRINGS- MCKENZIE BRIDGE, OREGON

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 56 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(5) PERFORATIONS:

Perforated? Yes No.
Type of perforator used MILLS KNIFE
Size of perforations 2 1/4 in. by 1/4 in.
72 perforations from 34 ft. to 51 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 30 gal./min. with 6 ft. drawdown after 2 hrs.
Artesian flow g.p.m.
Temperature of water 48° Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used PORTLAND CEMENT
Well sealed from land surface to 25 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 7 sacks
Number of sacks of bentonite used in well seal -0- sacks
Brand name of bentonite -0-
Number of pounds of bentonite per 100 gallons of water -0- lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County LANE Driller's well number
1/4 1/4 Section 11 T. 16s R. 6E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 37 ft.
Static level 34 ft. below land surface. Date 2-2-71
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing -0-
Depth drilled 56 ft. Depth of completed well 56 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOP SOIL - BROWN	0	3	
BOULDERS & SAND	3	17	
FINE SAND & GRAVEL/HEAVY CLAY	17	26	
CEMENTED GRAVEL	26	33	
GRAVEL-SAND-WATER BEARING	33	56	34

Work started 12-31-70 19 Completed 2-2- 19 71
Date well drilling machine moved off of well 2-3- 19 71

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Arthur N. Swin Date 2-8-71, 19
(Drilling Machine Operator)
Drilling Machine Operator's License No. 717

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name CARTER'S DRILLING & PUMP SERVICE
(Person, firm or corporation) (Type or print)
Address 325 SO. 2ND ST., SPRINGFIELD, OREGON
[Signed] Lemo J. Carter
(Water Well Contractor)
Contractor's License No. 126 Date 2-8-71, 19