

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER WELL REPORT

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON
(Please type or print)

LINC State Well No. 135/11w-27
State Permit No. _____
001548

(Do not write above this line)

(1) OWNER:

Name Oakland's Fish Camp
Address 4000 Hwy 34
Waldport, Or.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
C Jetted
D Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded

6" Diam. from 0 ft. to 20 ft. Gage 250
" Diam. from " ft. to " ft. Gage
" Diam. from " ft. to " ft. Gage

(6) PERFORATIONS:

Perforated? Yes No

Type of perforator used

Size of perforations in. by in.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

a pump test made? Yes No If yes, by whom? G&W
Yield: 9 gal./min. with 150 ft. drawdown after 2 hrs.
" " " " " "
" " " " " "
Pump test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.

Temperature of water 51 Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used cement
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 7 sacks
How was cement grout placed? pressure

Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.

Did any strata contain unusable water? Yes No

Type of water? _____ depth of strata _____

Method of sealing strata off _____

Was well gravel packed? Yes No Size of gravel: _____

Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Lincoln Driller's well number _____
1/4 1/4 Section 27 T. 13s R. 11w W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 185 ft.
Static level 32 ft. below land surface. Date 10/23/79
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 205 ft. Depth of completed well 205 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
topsoil	0	1	
sandy clay	1	8	
yellow clay	8	12	
gray clay	12	14	
brown sand & gravel	14	15	
gray clay	15	16	
gray claystone	16	45	
hd gray sandstone	45	105	
gray claystone	105	175	
gray broken claystone			
baring 9 gpm	175	205	

Work started 10/23/1979 Completed 10/23/1979
Date well drilling machine moved off of well 10/23/1979

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Ronald S. Witham Date 11/12/1979
(Drilling Machine Operator)

Drilling Machine Operator's License No. 503

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Raymond C. Gellatly & Ronald S. Witham
(Person, firm or corporation) (Type or print)

Address Philomath, Or. P.O. Box 1

[Signed] Raymond C. Gellatly
(Water Well Contractor)

Contractor's License No. 77 Date 11/12/1979