

NOTICE TO WATER WELL CONTRACTOR:  
The original and first copy of this report are to be filed with the

**RECEIVED**  
AUG 31 1972  
STATE OF OREGON  
WATER WELL REPORT  
LINC  
001571

State Well No. 13S/11W-27  
State Permit No. \_\_\_\_\_

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date of well completion.

**(1) OWNER:**

Name Lloyd Young  
Address 1/2 Fishin Hole Bx 250  
Star Route East, Waldport, Ore.

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
Cable  Jetted   
Dug  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**(5) CASING INSTALLED:**

Threaded  Welded   
6" Diam. from 0 ft. to 20 ft. Gage .250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

**(6) PERFORATIONS:**

Perforated?  Yes  No  
Type of perforator used \_\_\_\_\_  
Size of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

**(7) SCREENS:**

Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.  
" " " " "  
" " " " "  
Bailer test 5 gal./min. with 171 ft. drawdown after 2 hrs.  
Artesian flow g.p.m.  
Temperature of water 53 Depth artesian flow encountered ft.

**(9) CONSTRUCTION:**

Well seal—Material used Cement  
Well sealed from land surface to 18 ft.  
Diameter of well bore to bottom of seal 10 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 2 sacks  
Number of sacks of bentonite used in well seal - sacks  
Brand name of bentonite \_\_\_\_\_  
Number of pounds of bentonite per 100 gallons \_\_\_\_\_  
of water \_\_\_\_\_ lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(10) LOCATION OF WELL:**

County Lincoln Driller's well number \_\_\_\_\_  
1/4 1/4 Section 27 T. 13S R. 11W W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found 40 ft.  
Static level 14 ft. below land surface. Date 8/15/72  
Artesian pressure lbs. per square inch. Date \_\_\_\_\_

**(12) WELL LOG:**

Diameter of well below casing 6"  
Depth drilled 190 ft. Depth of completed well 190 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

| MATERIAL                          | From | To  | SWL |
|-----------------------------------|------|-----|-----|
| topsoil                           | 0    | 1   |     |
| sandy yellow clay                 | 1    | 10  |     |
| gray sandstone                    | 10   | 15  |     |
| light gray claystone              | 15   | 35  |     |
| hd. gray sandstone bearing 2 gpm  | 35   | 65  |     |
| gray sandstone                    | 65   | 90  |     |
| dark gray sandstone bearing 3 gpm | 90   | 120 |     |
| brown sandy clay                  | 120  | 145 |     |
| gray sandstone                    | 145  | 168 |     |
| hard lt. gray sandstone           | 168  | 178 |     |
| white sandy clay                  | 178  | 185 |     |
| gray sandy clay                   | 185  | 190 |     |

Work started 8/2/ 1972 Completed 8/15/ 1972  
Date well drilling machine moved off of well 8/15/ 1972

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Ronald S. Witham Date 8/26/72  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 503

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. W. Well  
Name Raymond C. Gellatly Contractor  
(Person, firm or corporation) (Type or print)  
Address Raymond C. Gellatly & Ronald S. Witham  
P.O. Box 1, Philomath, Oregon  
[Signed] ABOVE  
(Water Well Contractor)  
Contractor's License No. 77 Date 8/26/ 19.72