## WATER WELL REPORT STATE OF OREGON

## RECEIVED

AUG 9 1982

WATER RESOURCES DEPT.

State Well No. /.	39/11	W-27
State Permit No		

s	ALEM, OREGON
(1) OWNER:	(10) LOCATION OF WELL:
Name The Fishing Hole	County Kincoln Driller's well number
Address 3900 Hwy 34	4 4 Section 27 T. 13s Rllw W.M.
City Waldport State Or. 97394	Tax Lot # Lot Blk Subdivision
(2) TYPE OF WORK (check):	Address at well location:
New Well ☑ Deepening □ Reconditioning □ Abandon □	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 85 ft. Static level 8 ft. below land surface. Date 7/21/82
Rotary Air 🕱 Driven 🗆 Domestic 🛣 Industrial 🗆 Municipal 🗆	Artesian pressure   lbs. per square inch. Date
Rotary Mud   Dug   Irrigation   Test Well   Other     Thermal: Withdrawal   Reinjection	(12) WELL LOG: Diameter of well below casing
(5) CASING INSTALLED: Steel Plastic	Depth drilled 145 ft. Depth of completed well 145 ft.
(5) CASING INSTALLED: Steel	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
LINER INSTALLED:	MATERIAL From To SWL
4 "Diam from 0 ft. to 145 ft. Gauge 175	brown sand & clay 0 6
	brown clay 6 14
(6) PERFORATIONS: Perforated? ☼ Yes □ No Type of perforator used SaW	gray clay 14 16
Size of perforations 4 in by in	hd gray sandstone 16 55
20 perforations from 1/41 ft. to 160 ft.	hd gray claystone 5gpm   55 120
perforations fromft. toft.	gray sandstone 120 145
(7) SCREENS: Well screen installed? ☐ Yes 內 No	
Manufacturer's Name	
Type	
Diam Slot Size Set from ft. to ft.	
Diam. Slot Size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? ☐ Yes 🕱 No If yes, by whom?	
gal/min. with ft. drawdown after hrs.	
Air test 5 gal./min. with drill stem at 140t. 2 hrs.	
Bailer test gal./min. with ft. drawdown after hrs.	
Artesian flow g.p.m.	
perature of water 52 Depth artesian flow encountered ft.	Work started 7/21/19 82 Completed 7/21/ 1982
(9) CONSTRUCTION: Special standards: Yes □ No 🖫	Date well drilling machine moved off of well $7/21/$ 1982
Well seal—Material used <u>Cement</u>	Drilling Machine Operator's Certification:
Well sealed from land surface to	This well was constructed under my direct supervision. Materials used
Diameter of well bore to bottom of sealin.	and information reported above are true to my best knowledge and belief.
Diameter of well bore below seal	[Signed] (Drilling Machine Operator) Signed (Drilling Machine Operator)
Number of sacks of cement used in well seal	Drilling Machine Operator's License No
How was cement grout placed? ಟ್ರಸ್ಟಲ್ಲಿರು.ಎ.ಆಸ್ಟರ್	Water Well Contractor's Certification:
	This well was drilled under my jurisdiction and this report is true to
Was pump installed? Type HP Depth ft.	the best of my knowledge and belief
Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.	Name Raymond C. Gellatly & Ronald S. Witham (Person, firm or corporation) (Type or print)
Did any strata contain unusable water?   Yes  No	Address P.C. Box 1, Philomath, Or.
Type of Water? depth of strata	[Signed] Royal & Withern
Method of sealing strata off	(Water Well Contractor)
Was well gravel packed? ☐ Yes XXNO Size of gravel:	Contractor's License No. 503Date
Graver placed from	