

NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM 10, OREGON
within 30 days from the date
of well completion.

RECEIVED
MAY 27 1964
STATE ENGINEER

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

State Well No. 6/10W-30M

State Permit No. _____

(1) OWNER:

Name

A. VOIGTLE

Address

Box 222
OTIS, ORE.

(2) LOCATION OF WELL:

County Lincoln Driller's well number _____1/4 Section 30 T. 6 R. 10-WEST W.M.

Bearing and distance from section or subdivision corner

1-MILE-WEST-OF-OTISN-HY. 18

(3) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:

Threaded ☐ Welded ☒

_____ " Diam. from _____ ft. to _____ ft. Gage _____

_____ " Diam. from 0 ft. to 22 ft. Gage 240

_____ " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? ☐ Yes ☒ No

Type of perforator used _____

Size of perforations _____ in. by _____ in.

_____ perforations from _____ ft. to _____ ft.

_____ perforations from _____ ft. to _____ ft.

_____ perforations from _____ ft. to _____ ft.

_____ perforations from _____ ft. to _____ ft.

_____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name _____

Type _____ Model No. _____

_____ " Diam. Slot size _____ Set from _____ ft. to _____ ft.

_____ " Diam. Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite clayDepth of seal 18 ft. Was a packer used? noDiameter of well bore to bottom of seal 10 in.Were any loose strata cemented off? ☐ Yes ☒ No Depth _____Was a drive shoe used? ☐ Yes ☒ NoWas well gravel packed? ☐ Yes ☒ No Size of gravel: _____

Gravel placed from _____ ft. to _____ ft.

Did any strata contain unusable water? ☐ Yes ☒ NoType of water? _____ Depth of strata 16Method of sealing strata off using drive in rock

(10) WATER LEVELS:

7.98' 10/30/64 WSBStatic level 6 ft. below land surface Date 5-5-64

Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is

lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.

" " " "

" " " "

Bailer test 10 gal./min. with 14 ft. drawdown after 3 hrs.

Artesian flow _____ g.p.m. Date _____

Temperature of water 49 Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG:

Diameter of well below casing 5 3/4Depth drilled 32 ft. Depth of completed well 32 ft.

Formation: Describe by color, character, size of material and structure, and
show thickness of aquifers and the kind and nature of the material in each
stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>black top soil</u>	<u>0</u>	<u>4'</u>
<u>yellow clay - small rock</u>	<u>4</u>	<u>16</u>
<u>hard grey clay stone</u>	<u>16</u>	<u>29</u>
<u>small river gravel - water bearing</u>	<u>29</u>	<u>32</u>

Work started 12-26 1963 Completed 4-2 1964Date well drilling machine moved off of well 4-9 1964

(13) PUMP:

Manufacturer's Name _____

Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

NAME KULICK-WELL-DRILLING
(Person, firm or corporation) (Type or print)

Address 905-Mill St Sheridan ore.Drilling Machine Operator's License No. 48

[Signed] H. L. Kulick
(Water Well Contractor)

Contractor's License No. 78 Date 5-5, 1964