

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310, within 30 days from the date of well completion.

RECEIVED
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT

STATE OF OREGON

JUL 19 1967 (Please type or print)
 (Do not write above this line)

LINC 4/43
~~117~~

State Well No. 6/10w-33 **B**

State Permit No. G-4071

(1) OWNER:

Name Lawrence A. and Betty Du Rette, and
 Address F. Ralph and Evelyn G. Du Rette, Rte. 1,
box 59, Otis, Oregon 97368

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
 8" Diam. from 1 ft. to 85 1/2 ft. Gage 258
 " Diam. from above ft. to ft. Gage
 " Diam. from surf. ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.

Type of perforator used

Size of perforations in. by in.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
 Type Model No.
 Diam. Slot size Set from ft. to ft.
 Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 8 2/3 ft. below land surface Date 5/25/67
 Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? driller
 Yield: 26 gal./min. with 46 ft. drawdown after 3 hrs.
28 " " 59 " " 7 1/2 "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water 48 Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used bentonite
 Depth of seal 19 ft.
 Diameter of well bore to bottom of seal 18 in.
 Were any loose strata cemented off? Yes No Depth
 Was a drive shoe used? Yes No
 Did any strata contain unusable water? Yes No
 Type of water? depth of strata
 Method of sealing strata off
 Was well gravel packed? Yes No Size of gravel 1/2 minus
 Gravel placed from 19 ft. to 24 ft.

(11) LOCATION OF WELL:

County Lincoln Driller's well number #300
 Box 1/4 Section 33 T. 6S. R. 10W. W.M.

Bearing and distance from section or subdivision corner Well-
1216.69 feet South and 1215.62 feet East
of the Northwest corner of the Northeast
1/4 of section 33, T6S., R10W. of the W.M.

(12) WELL LOG:

Diameter of well below casing 8 inch

Depth drilled 165 ft. Depth of completed well 161 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
brown clay	-	12	
brown clay and rock mixed	12	30	
grey clay, and rock and (clayhard)	30	36	
grey hard shale and rock mixed	36	61	60
grey hard shale and rock mixed	61	132	130
grey shale	132	161	155

Work started 5/19 1967 Completed 6/1 1967

Date well drilling machine moved off of well 6/1 1967

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Charles Panschow Date 7/17, 1967
 (Drilling Machine Operator)

Drilling Machine Operator's License No. 163

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Charles Panschow, Rte. 1, box 102
 (Person, firm or corporation) (Type or print)

Address Florence, Oregon 97439

[Signed] Mabel Panschow
 (Water Well Contractor)

Contractor's License No. 87 Date 7/17, 1967