NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

LINC 503

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

RECEIVED DEC 31 1963 STATE ENGINEER SALEM, OREGON

State Well No. 6/10W-35 E1
State Permit No.

(1) OWNER:
Name K. A. HARTBERG
Address BOX 45
ROSE LODGE ORE.

(2) LOCATION OF WELL:
County LINCLON Driller's well number
¼ ¼ Section 34 & 35 T. 6 SOUTH R. 10 W.M.
Bearing and distance from section or subdivision corner
¼ SEC. 2 & 3 - T. 7 - SOUTH - R. 10 W.W.M.
1 MILE WEST OF ROSELODGE ORE.
4 BLKS OF SALMON RIVER

(3) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☒
" Diam. from ft. to ft. Gage
6 " Diam. from 0 ft. to 9 ft. Gage 240
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? ☐ Yes ☒ No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Cement
Depth of seal 20 ft. Was a packer used? no
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? ☒ Yes ☐ No Depth 24'
Was a drive shoe used? ☐ Yes ☒ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? Depth of strata
Method of sealing strata off Cement

(10) WATER LEVELS: 14.80 2/17/65 WSB
Static level 8 ft. below land surface Date 12-9-63
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 8 gal./min. with 40 ft. drawdown after 3 hrs.
Artesian flow g.p.m. Date
Temperature of water 49 Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 65' ft. Depth of completed well 65 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifiers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
YELLOW-CLAY-LARGE-BOULDERS	0	14
BLUE CLAY	14	18
GREY-SAND-STONE-	18	20
HARD-CLAY-STONE-GREY	20	28
POURS-SAND-STONE-GREY-WATER-B.	28	29
HARD-SOLID-ROCK-LIGHT-BLACK	29	49
POURS-SAND-STONE-GREY-WATER-B.	49	56
HARD-CLAY-STONE-GREY	56	65

Work started 10-26 1963 Completed 11-20 1963
Date well drilling machine moved off of well 11-26 1963

(13) PUMP: ✓ USED
Manufacturer's Name FAIR-BANK MOORS
Type: JET H.P. 1½

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME KULICK-WELL-DRILLING (Person, firm or corporation) (Type or print)
Address 905-MILL-SHERIDAN-ORE.
Drilling Machine Operator's License No. 48
[Signed] G. L. Kulick (Water Well Contractor)
Contractor's License No. 78 Date 12-10-, 1963

(USE ADDITIONAL SHEETS IF NECESSARY)