

NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM 10, OREGON
within 30 days from the date
of well completion.

WATER WELL REPORT

SEP 20 1962

STATE OF OREGON
(Please type or print)

LINC

State Well No. 10/10W-36A

State Permit No.

(1) OWNER:

Name

Address

(2) LOCATION OF WELL:

County

Driller's well number

1/4

1/4 Section

36

T. 10S

R. 10W

W.M.

Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:

Threaded ☐ Welded ☒

6" Diam. from 0 ft. to 32 ft. Gage 250

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? ☐ Yes ☒ No

Type of perforator used

Size of perforations	in. by	in.
perforations from	ft. to	ft.
perforations from	ft. to	ft.
perforations from	ft. to	ft.
perforations from	ft. to	ft.
perforations from	ft. to	ft.

(8) SCREENS:

Well screen installed ☐ Yes ☒ No

Manufacturer's Name

Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal

Depth of seal 22 ft. Was a packer used? No

Diameter of well bore to bottom of seal 10 in.

Were any loose strata cemented off? ☐ Yes ☒ No DepthWas a drive shoe used? ☐ Yes ☒ NoWas well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water?

Depth of strata

Method of sealing strata off

(10) WATER LEVELS:

Static level 23 ft. below land surface Date Sept 21

Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☐ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Bailer test 8 gal./min. with 46 ft. drawdown after 1 hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 68 ft. Depth of completed well 68 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Soil (sandy)	0	6
Clay Brown	6	18
Sandstone Blue	18	35
Claystone Blue (Hard)	35	62
Claystone Water Bearing	62	68

Very little iron - H₂S?

Sample # 150

note new address

Work started Sept 19 19 Completed Sept 21 1962

Date well drilling machine moved off of well Sept 21 19

(13) PUMP:

Manufacturer's Name

Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME

G. H. Pruitt Well Drilling

Address

1993 CRK Creek Rd.

Drilling Machine Operator's License No.

[Signed]

G. H. Pruitt

Contractor's License No. 23 Date Sept 22, 1962