NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED DEC 6 1966 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

LINN 10404

State Well No. 12/3w-4

State Permit No.

(1) OWNER:

Name T. L. KUHNS CO.

Address 1067 12th St. SE
SLAEM, OREGON

(2) LOCATION OF WELL:

County LINN Driller's well number

¼ ¼ Section 4 T. 12 S R. 3 W W.M.

Bearing and distance from section or subdivision corner
Junction Interstate 5 and Hwy. 34
American Oil Co. Station

(3) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐
Service station

(5) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☒

6" Diam. from 0 ft. to 104 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? ☐ Yes ☒ No

Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed? ☐ Yes ☒ No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite
Depth of seal 22 ft. Was a packer used? no
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☒ Yes ☐ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 15 ft. below land surface Date 12/1/66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 30 gal./min. with 10 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG: Diameter of well below casing 0

Depth drilled 104 ft. Depth of completed well 104 ft.

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Gravel fill	0	2
Clay-surface, gray	2	6
Clay-yellow	6	22
Gravel and sand-brown clay	22	40
Sand-brown	40	53
Clay-sandy, brown, some gravel	53	78
Clay-blue, sandy	78	98
Gravel and sand-black	98	104
Water above 78' from dirty clay formation----- shut off		

Work started 11/28/66 19 Completed 12/1/66 19
Date well drilling machine moved off of well 12/1/66 19

(13) PUMP: Not installed

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME DUFFIELD BROS
(Person, firm or corporation) (Type or print)
Address 4123 BLUFF AVE S E, SALEM, OREGON

Drilling Machine Operator's License No. 47

[Signed] L. Burnard Duffield
(Water Well Contractor)

Contractor's License No. 15 Date Dec. 4, 1966

(USE ADDITIONAL SHEETS IF NECESSARY)