

RECEIVED

WATER WELL REPORT

LINN 10615

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

JUL 5 1961

STATE OF OREGON G2183

State Well No. 12/4W-7B

State Permit No.

(1) OWNER:

STATE ENGINEER SALEM, OREGON

Name Willard Hamlin Address Corvallis, Oregon

(2) LOCATION OF WELL:

County Benton Owner's number, if any-- NW 1/4 NE 1/4 Section 7 T. 12S R. 4W W.M. Bearing and distance from section or subdivision corner 7 chains South and 38 chains East from NW corner see 7

(3) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ] If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [X] Test Well [ ] Other [ ]

(5) TYPE OF WELL:

Rotary [ ] Driven [ ] Cable [X] Jetted [ ] Dug [ ] Bored [ ]

(6) CASING INSTALLED:

10" Diam. from 0 ft. to 30'7" ft. Gage STD

(7) PERFORATIONS:

Perforated? [X] Yes [ ] No Type of perforator used acetylene torch SIZE of perforations 6 in. by 3/16 in. 78 perforations from 21 ft. to 30'7" ft.

(8) SCREENS:

Well screen installed [ ] Yes [X] No Manufacturer's Name Type Model No. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? [ ] Yes [ ] No Size of gravel: Gravel placed from ft. to ft. Was a surface seal provided? [ ] Yes [ ] No To what depth? ft. Material used in seal-- Did any strata contain unusable water? [ ] Yes [ ] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 14'6" ft. below land surface Date 5-24-61 Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] W. G. Hamlin Date 5-31-61, 19 (Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Table with columns: Yield (gal./min.), drawdown (ft.), time (hrs). Includes Bailer test and Artesian flow data.

(12) WELL LOG:

Diameter of well 10 inches. Depth drilled 30'7" ft. Depth of completed well 30'7" ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Lists soil types like topsoil, sandy clay, coarse gravel, etc.

Work started 5-28-61 19 Completed 5-24-61 19

(13) PUMP:

Manufacturer's Name Cornell Pump Co. Type Centrifugal 3" H.P. 15

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Raymond C. Gellatly (Person, firm, or corporation) (Type or print)

Address Box 1 Philomath, Oregon

Driller's well number

[Signed] Raymond C. Gellatly (Well Driller)

License No. 77 Date 5-31-61 19