RECEIVED APR 2 1964 STATE ENGINEER SALEM, OREGON

LINN 10651

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. 12/4W-8B

State Permit No. G-3053

(1) OWNER:

Name Mr. R. G. Gates

Address 3000 White Oak Drive
Corvallis, Oregon

(2) LOCATION OF WELL:

County Linn Driller's well number

NW ¼ NE ¼ Section 8 T. 12 S R. 4 W W.M.

Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☒

" Diam. from ft. to ft. Gage 1#
10" Diam. from 1 Ft. above ground ft. to level
" Diam. from 40 Ft. below ground ft. to level ft. Gage

(7) PERFORATIONS: Perforated? ☒ Yes ☐ No

Type of perforator used Cutting Torch

Size of perforations 3/8 in. by 8 in.

perforations from ft. to ft.
52 perforations from 28 ft. to 38 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite

Depth of seal 18 ft. Was a packer used?

Diameter of well bore to bottom of seal 14 in.

Were any loose strata cemented off? ☐ Yes ☒ No Depth

Was a drive shoe used? ☒ Yes ☐ No

Was well gravel packed? ☒ Yes ☐ No Size of gravel: #2 round

Gravel placed from 18 ft. to 40 ft.

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? Depth of strata

Method of sealing strata off

(10) WATER LEVELS:

Static level 8 ft. below land surface Date 4/8/64

Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom? R.G.Gates

Yield: 600 gal./min. with 18 ft. drawdown after 3 hrs.
" " " "
" " " "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water 48° Was a chemical analysis made? ☐ Yes ☐ No

(12) WELL LOG: Diameter of well below casing - - - - -

Depth drilled 40 ft. Depth of completed well 40 ft.

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Top Soil	0	4'
Brown Clay	4'	18'
Sand & Gravel	18'	32'
Medium Gravel - water bearing	32'	40'

Work started April 8, 1964 Completed April 10, 1964

Date well drilling machine moved off of well April 11, 1964

(13) PUMP:

Manufacturer's Name

Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME ART CLINTON WELL DRILLING CO.
(Person, firm or corporation) (Type or print)

Address Rt1, Box 2, Independence, Oregon

Drilling Machine Operator's License No. 34

[Signed] Art Clinton
(Water Well Contractor)

Contractor's License No. 14 Date April 20, 1964

(USE ADDITIONAL SHEETS IF NECESSARY)