RECEIVED
NOV 27 1984
WATER RESOURCES DEPT.
SALEM, OREGON

LINN 11141

State Well No. 13S/1W-14dc

State Permit No. .....

WATER WELL REPORT
STATE OF OREGON

PLEASE TYPE OR PRINT IN INK

(1) OWNER:
Name JAMES GOSSETT
Address 28780 PLEASANT VALLEY RD.
City SWEET HOME 97386 State OREGON

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary Air ☐ Driven ☐
Rotary Mud ☒ Dug ☐
Cable ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐
Thermal: Withdrawal ☐ Reinjection ☐

(5) CASING INSTALLED:
Steel ☒ Plastic ☐
Threaded ☐ Welded ☒
6" Diam. from +1 ft. to 42 ft. Gauge 250
" Diam. from ft. to ft. Gauge

LINER INSTALLED:
" Diam. from ft. to ft. Gauge

(6) PERFORATIONS:
Perforated? ☒ Yes ☐ No
Type of perforator used MILLS KNIFE
Size of perforations 1/4 in. by 3 in.
12 perforations from 28 ft. to 35 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
Air test gal./min. with drill stem at ft. hrs.
Bailer test 10 gal./min. with 11 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 54 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Special standards: Yes ☐ No ☒
Well seal—Material used cement
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 18 sacks
How was cement grout placed? tube outside casing
Was pump installed? no Type HP Depth ft.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County LINN Driller's well number
S.W¼ S.E.¼ Section 14 T. 13S R. 1W W.M.
Tax Lot # 2604 Lot Blk Subdivision
Address at well location: same

(11) WATER LEVEL: Completed well.
Depth at which water was first found 32 ft.
Static level 20'4" ft. below land surface. Date 11/12
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 6"
Depth drilled 102 ft. Depth of completed well 75 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil, sandy	0	3	
Soil, boulders & gravel	3	10	
clay & boulders	10	20	
" & gravel	20	30	
" & sand gray	30	34	22'
" & gravel, brown	34	36	
Conglomerate, blue	36	70	
Claystone, red brown	70	102	20'4
bailer & fishing tool could not be recovered.			

Work started 10/26 1984 Completed 11/12 1984
Date well drilling machine moved off of well 11/12 1984

(unbonded) Water Well Constructor Certification (if applicable):
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Date, 19

Bonded Water Well Constructor Certification:
Bond SLR6386707 (number) Issued by: Firemans Fund (Surety Company Name)
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name H&H DRILLING (Person, firm or corporation) (Type or print)
Address 39081 Golden Valley Dr. Lebanon, Or.
[Signed] [signature] Water Well Constructor
Date 11/19, 19 84

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*45292-690