

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

DEC 11 1964

STATE OF OREGON (Please type or print)

LINN 11428

State Well No. 13/W-34

State Permit No.

(1) OWNER:

Name Sweet Home Cemetery
Address Maintenance District
P.O. Box 453 Sweet Home Ore.

(2) LOCATION OF WELL:

County Linn Driller's well number 20-64
1/4 Section 34 T. 13-S R. 1-E, W.M.
Bearing and distance from section or subdivision corner

Gilliland Cemetery

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 44 ft. Gage F/7.02
" Diam. from " ft. to " ft. Gage
" Diam. from " ft. to " ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used
Size of perforations in. by in.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Model No.
Diam. Slot size Set from " ft. to " ft.
Diam. Slot size Set from " ft. to " ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite
Depth of seal 20 ft. Was a packer used? no
Diameter of well bore to bottom of seal 9 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from " ft. to " ft.
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 39 ft. below land surface Date 12-8-64
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Bailer test 11 gal./min. with 45 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 100 ft. Depth of completed well 100 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Soil	0	1
Red Brown Clay	1	20
Light Brown Clay	20	42
Brown Sandstone	42	52
Green Blue Sandstone	52	100

Work started 11-24 1964 Completed 12-5 1964
Date well drilling machine moved off of well 12-8 1964

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Jack Witzcraft Well Drilling
(Person, firm or corporation) (Type or print)

Address 1803 River St. Sweet Home Ore

Drilling Machine Operator's License No. 153

[Signed] J. J. Witzcraft
(Water Well Contractor)

Contractor's License No. 127 Date 12-8, 1964