NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT GEVE

N STATE OF OREGON JUN 1 4 1973 state Well No. 12

(Please type or pull) ATE ENGINETE Permit No.

(Do not write above this line) LEM. OREGON

(1) OWNER: Name City of Brownsville	(10) LOCATION OF WELL: County Linn Driller's well number 57573G
Address Brownsville, Oregon 97327	AUR CIR 24 A2C OU
1 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3	NE 14 SE 14 Section 31 T. 133 R. 2W W.M. Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	bearing and distance from section of subdivision corner
New Well X Deepening □ Reconditioning □ Abandon □	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	
Potony II Dwiston II	Depth at which water was first found 12 ft. Static level 8 ft below land surface. Data 5=9=73
Cable 🕅 Jetted 🗌 Domestic 📋 industrial 📋 Municipal 📋	Static level 8 ft. below land surface. Date 5-9-73
Dug	Artesian pressure lbs. per square inch. Date
CASING INSTALLED: Threaded □ Welded to the tome of t	(12) WELL LOG: Diameter of well below casing
PERFORATIONS: Perforated? Yes X No.	with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used Torch	MATERIAL From To SWL
	12
a. 90 perforations from 12 ft. to 30 ft.	Sandy loam 0 3
b. 14 perforations from ft. to ft.	Gravel, coarse, silty 3 14
perforations from ft. to ft.	Gravel, coarse to fine 14 26
(7) SCREENS: Well screen installed? Yes **No	Rhyolite, fractured 26 32
(1) SCREENS: Well screen installed? Well screen installed? Yes X No Manufacturer's Name	
Type Model No.	4 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
Diam. Slot size Set from ft. to ft.	
Diam	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? W Yes No If yes, by whom Schoon Elect	r <u>. </u>
Yield: gal./min. with ft. drawdown after hrs.	
" " "	
H H	
Bailer test 60 gal./min. with 0 ft. drawdown after 2 hrs.	<u> </u>
Artesian flow g.p.m.	
perature of water 54 Depth artesian flow encountered ft.	Work started 5-8 19 73 Completed 5-9 1973
(9) CONSTRUCTION:	Date well drilling machine moved off of well 5-9 1973
Well seal—Material used Cement	Drilling Machine Operator's Certification:
Well sealed from land surface toft.	This well was constructed under my direct supervision. Materials used and information reported above are true to my
Diameter of well bore to bottom of sealin.	best knowledge and belief.
Diameter of well bore below seal	[Signed] Date 5//, 1973
Number of sacks of cement used in well seal8 sacks	Drilling Machine Operator) Drilling Machine Operator's License No. 738
Number of sacks of bentonite used in well seal sacks	Drining Machine Operator's License No
Brand name of bentonite	Water Well Contractor's Certification:
Number of pounds of bentonite per 100 gallons	This well was drilled under my jurisdiction and this report is
of waterlbs./100 gals. Was a drive shoe used? Wes □ No Plugs Size: location ft.	true to the best of my knowledge and belief.
Did any strata contain unusable water? Yes XXNo	Name Schoon Electric and Pump (Person, firm or corporation), (Type or print)
Type of water? depth of strata	Address 626 W. Queen/Albany, Oregon 97321
Method of sealing strata off	5. 9.16.
	[Signed] (Water Well Contractor),
Was well gravel packed? ☐ Yes ☒ No Size of gravel:	513 5////73
Gravel placed from ft. to ft.	Contractor's License No. 513 Date 5/1/ 19 19