

NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97301
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

State Well No.

State Permit No.

(1) OWNER:

Name **John Pugh & Son**
Address **Box #190 Shedd, Ore.**

(2) LOCATION OF WELL:

County **Linn** Driller's well number **Repair**
NW 1/4 NW 1/4 Section **18** T. **13S** R. **3W** W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well ☐ Deepening ☐ Reconditioning ☒ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:

Threaded ☐ Welded ☐

" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? ☒ Yes ☐ NoType of perforator used **Mills**

Size of perforations **1/4** in. by **2** in.
200 perforations from **100** ft. to **80** ft.
100 perforations from **70** ft. to **60** ft.
50 perforations from **45** ft. to **40** ft.
50 perforations from **35** ft. to **25** ft.
..... perforations from ft. to ft.

(8) SCREENS:

Well screen installed? ☐ Yes ☐ No

Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal
Depth of seal ft. Was a packer used?
Diameter of well bore to bottom of seal in.
Were any loose strata cemented off? ☐ Yes ☐ No Depth
Was a drive shoe used? ☐ Yes ☐ No
Was well gravel packed? ☐ Yes ☐ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? ☐ Yes ☐ No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level **6** ft. below land surface Date **12/16/64**
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(12) WELL LOG:

Diameter of well below casing

Depth drilled ft. Depth of completed well ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL

FROM

TO

Removed Turbine pump from well,
perforated and swabed & cleaned.
Pump column and shaft coated 1/4 in.
with scale.

This well constructed by Hamilton
Drilling of Albany, Ore. 1959.

Work started **12/15/64** Completed **12/16/64** 19Date well drilling machine moved off of well **12/16/64** 19

(13) PUMP:

Manufacturer's Name

Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME **Pete Tolmasoff Well Drilling**

(Person, firm or corporation)

(Type or print)

Address **Turner, Ore.**Drilling Machine Operator's License No. **320**

[Signed]

(Water Well Contractor)

Contractor's License No. **410** Date **12/18/64** 19

(USE ADDITIONAL SHEETS IF NECESSARY)