

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

RECEIVED
1/19/81
STATE OF OREGON
(Please type or print)

LINN well #3

State Well No. 13/310-34a
State Permit No. _____

STATE ENGINEER
SALEM OREGON

(1) OWNER:

Name Peter Jensen
Address Rt. 1, Box 46
Brownsville, Oregon

(2) LOCATION OF WELL:

County Linn Driller's well number _____
1/4 Section 34 T. 13S R. 3W W.M.
Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):

Draw Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other
Rotary Cable Dug Driven Jetted Bored

(5) TYPE OF WELL:

Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED:

Threaded Welded
10" Diam. from 0 ft. to 79'03" ft. Gage 250 Wall
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used Acetylene Torch
Size of perforations 1/8 in. by 12 in.
58 perforations from 64.109 ft. to 79.03 ft.
30 perforations from 25 ft. to 35 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentomite
Depth of seal 18 ft. Was a packer used? _____
Diameter of well bore to bottom of seal 14 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 4 ft. below land surface Date 12-6-65
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: 190 gal./min. with 70 ft. drawdown after 2 hrs.
" Stettler Supply, Salem, Ore. "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 10"
Depth drilled 95 ft. Depth of completed well 95 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0	3
Clay	3	8
Clay & Gravel	8	30
Blue Clay	30	57
Clay & Gravel	57	61
Sandy Clay & Gravel	61	63
Sand & Gravel	63	78
Blue Clay	78	95

Work started 12-2 1965 Completed 12-6 1965
Date well drilling machine moved off of well _____ 19 _____

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Merle Warren Well Drilling
(Person, firm or corporation) (Type or print)
Address Rt. 1, Box 85, Tangent, Oregon
Drilling Machine Operator's License No. 313
[Signed] Merle Warren
(Water Well Contractor)
Contractor's License No. 182 Date 12-7 1965