NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
OCT 19 1966
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

LINN
12066

State Well No. 13/4W-16F
State Permit No. G-4475

(1) OWNER:
Name Richard Pimm
Address Shedd, Oregon

(2) LOCATION OF WELL:
County Linn Driller's well number
¼ ¼ Section 16 T. 13S R. 4W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well [X] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic [] Industrial [] Municipal []
Irrigation [X] Test Well [] Other []

(5) TYPE OF WELL:
Rotary [] Driven []
Cable [X] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:
Threaded [] Welded [X]
8 " Diam. from +2 to 104½ ft. Gage 250 Wall
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:
Perforated? [X] Yes [] No
Type of perforator used Acetylene Torch
Size of perforations 3/8 in. by 12 in.
42 perforations from 42 ft. to 54 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed? [] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Bentonite
Depth of seal 18 ft. Was a packer used?
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? [] Yes [X] No Depth
Was a drive shoe used? [X] Yes [] No
Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 9'06" ft. below land surface Date 10-10-66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [] No If yes, by whom? Stettler Supp. Salem, Ore.
Yield: 300 gal./min. with 38 ft. drawdown after 2 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [] Yes [X] No

(12) WELL LOG:
Diameter of well below casing
Depth drilled 56 ft. Depth of completed well 56 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Top Soil	0	2
Clay	2	17
Gravel	17	35
Clay & Gravel	35	38
Sand & Gravel	38	48
Black Sand & Pea Gravel	48	56

Work started 10-7 1966 Completed 10-10 1966
Date well drilling machine moved off of well 10-10 1966

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Merle Warren Well Drilling
(Person, firm or corporation) (Type or print)
Address Rt. 1, Box 85, Tangent, Oregon
Drilling Machine Operator's License No. 313
[Signed] Merle Warren
(Water Well Contractor)
Contractor's License No. 182 Date 10-14, 1966

(USE ADDITIONAL SHEETS IF NECESSARY)