

RECEIVED

JAN 15 1962

LINN
12887

13/1-34

File Original and
First Copy with the
STATE ENGINEER,
SALEM, OREGON

STATE ENGINEER WATER WELL REPORT
SALEM, OREGON STATE OF OREGON

State Well No.

State Permit No.

(1) OWNER:

Name Sweet Home Cemetery Maint. Dist.
Address 1443 W. St
Sweet Home, ORE.

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level.

Was a pump test made? Yes No If yes, by whom? -
Yield: .50 gal./min. with all ft. drawdown after 24 hrs.

(2) LOCATION OF WELL:

County LINN Owner's number, if any—
1/4 1/4 Section 24 T. 13S R. 1E W.M.
Bearing and distance from section or subdivision corner

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water 52 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 6 inches.

Depth drilled ft. Depth of completed well 335 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used

SIZE of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel:

Gravel placed from ft. to ft.

Was a surface seal provided? Yes No To what depth? ft.

Material used in seal—

Did any strata contain unusable water? Yes No

Type of water? Depth of strata

Method of sealing strata off

(10) WATER LEVELS:

Static level 60 ft. below land surface Date 1-3-62

Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] K.A. Lucey Sec Date 1-8, 1962
(Owner)

(13) PUMP:

Manufacturer's Name

Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Willamette Irrigation & Equip Co.
(Person, firm, or corporation) (Type or print)

Address Star Route #2, Box 5, Lebanon

Driller's well number

[Signed] Carl H Saunders
(Well Driller)

License No. 49 Date 1-3, 1961