

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the  
STATE ENGINEER, SALEM 10, OREGON  
within 30 days from the date  
of well completion.

**RECEIVED**  
DEC 14 1962  
STATE ENGINEER

# WATER WELL REPORT

STATE OF OREGON  
(Please type or print)

**LINN**  
12992 State Well No. 13/16E-35  
State Permit No. \_\_\_\_\_

(1) OWNER:  
Name U.S. Forest Service  
Address P.O. Box 405  
Sunset Home, Oregon.

(2) LOCATION OF WELL:  
County LINN Driller's well number 6E  
35 Section T. 138 R. 1W? W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

PROPOSED USE (check):  
Domestic  Industrial  Municipal  Irrigation  Test Well  Other   
(5) TYPE OF WELL:  
Rotary  Driven  Cable  Jetted  Dug  Bored

(6) CASING INSTALLED:  
Threaded  Welded  5/16  
6" Diam. from 0 ft. to 30 ft. Gage 9/16

(7) PERFORATIONS:  
Perforated?  Yes  No  
Type of perforator used \_\_\_\_\_  
Size of perforations in. by in.  
..... perforations from ..... ft. to ..... ft.  
..... perforations from ..... ft. to ..... ft.  
..... perforations from ..... ft. to ..... ft.  
..... perforations from ..... ft. to ..... ft.  
..... perforations from ..... ft. to ..... ft.

(8) SCREENS:  
Well screen installed  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(9) CONSTRUCTION:  
Well seal—Material used in seal Bentonite  
Depth of seal 21 ft. Was a packer used? No  
Diameter of well bore to bottom of seal 10 in.  
Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(10) WATER LEVELS:  
Static level 11 ft. below land surface Date 12-5-62  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

(11) WELL TESTS:  
Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.  
..... " " " " " "  
..... " " " " " "  
Bailer test 50 gal./min. with 5 ft. drawdown after 1 hrs.  
Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
Temperature of water 32 Was a chemical analysis made?  Yes  No

(12) WELL LOG:  
Diameter of well below casing \_\_\_\_\_  
Depth drilled 30 ft. Depth of completed well 30 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>Soil</u>	<u>0</u>	<u>6</u>
<u>SLAB rock</u>	<u>6</u>	<u>24</u>
<u>AVA SAND</u>	<u>24</u>	<u>28</u>
<u>AVA glass</u>	<u>28</u>	<u>30</u>

Work started 11 28 1962 Completed 12-6 1962  
Date well drilling machine moved off of well 12-6 1962

(13) PUMP:  
Manufacturer's Name \_\_\_\_\_  
Type: \_\_\_\_\_ H.P. \_\_\_\_\_

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
NAME Wallamette Irrigation & Equip Co.  
(Person, firm or corporation) (Type or print)  
Address Star Route #2, Box 5, Lebanon  
Drilling Machine Operator's License No. 91  
[Signed] Carl H. Saunders  
(Water Well Contractor)  
Contractor's License No. 79 Date 12-5, 1962