NC

LINN
13422

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
AUG 17 1965
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. 14/2w-8add

G-4746 State Permit No.

(1) OWNER:
Name ~~Floyd Kramer~~
Address ~~Courtney Creek Road~~
~~Brownsville, Oregon~~

(2) LOCATION OF WELL:
County Linn Driller's well number
¼ ¼ Section 8 T. 14S R. 3W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:
Threaded ☐ Welded ☒
10" Diam. from +1' 3½" ft. to 75 ft. Gage 250Wall
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:
Perforated? ☒ Yes ☐ No
Type of perforator used Acetylene Torch
Size of perforations ½ in. by 12 in.
73 ~~XX~~ perforations from 54 ft. to 75 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Bentonite
Depth of seal 18 ft. Was a packer used?
Diameter of well bore to bottom of seal 14 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☒ Yes ☐ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 11 ft. below land surface Date 7-28-65
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☐ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 85 gal./min. with 20 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG:
Diameter of well below casing
Depth drilled 75 ft. Depth of completed well 75 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Top Soil	0	7
Clay & Gravel	7	41
Clay	41	45
Gravel	45	46
Clay & Gravel	46	54
Clay	54	61
Water Gravel	61	72
Clay & Gravel	72	75

Work started 7-24 19 65 Completed 7-28 19 65
Date well drilling machine moved off of well 7-29 19 65

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Merle Warren Well Drilling
(Person, firm or corporation) (Type or print)
Address Rt. 1, Box 85, Tangent, Oregon
Drilling Machine Operator's License No. 313
[Signed] Merle Warren
(Water Well Contractor)
Contractor's License No. 182 Date 8-5, 19 65

(USE ADDITIONAL SHEETS IF NECESSARY)