WATER WELL REPORT STATE OF OREGON

RECEIVED

LINN

JAN261981

13533

ii J		
State Permit No.		• •
Secretary .	10178	

WATER RESOURCES DEPT SALEM, OREGON

		•
State Permit No.		••••••
**************************************	6-9138	

(I) OWNER:	(10) LOCATION OF WELL:		
Name John Koos & Sons	County Linn Driller's well n	umber 161-12-80	
Address 30929 Seven Mile Ln.	SW ¼ SW ¼ Section 1 T. 14SI	r. 3W w.m.	
City Tangent State Ore.	Tax Lot # Lot Blk	Subdivision	
(2) TYPE OF WORK (check):	Address at well location:		
New Well ☑ Deepening □ Reconditioning □ Abandon □			
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed we	II.	
	Depth at which water was first found	84 ft.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):		d surface. Date 1/9/81	
Air □ Driven □ Domestic □ Industrial □ Municipal □ Rosary Mud □ Dug □ Irrigation X Test Well □ Other □	·	square inch. Date	
Roady Mud			
(E) CACTAC TACTACT TO T		sing 16 in.	
(5) CASING INSTALLED: Steel Entered Welded N			
Threaded Welded XI 71 ft. to	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry		
"Diam. fromft. toft. Gauge	for each change of formation. Report each change in pos and indicate principal water-bearing strata.	sition of Static Water Level	
LINER INSTALLED:			
·		From To SWL	
	top soil	0 4	
(6) PERFORATIONS: Perforated? ☐ Yes 🛣 No	clay brown	4 24	
Type of perforator used	clay blue sandy	24 65	
Size of perforations in. by in.	clay blue hard	65 84	
perforations from ft. to ft.	claystone grey heavy sanded	84 95	
perforations from ft. to ft.	claystone hard	95 102	
perforations from ft. to ft.		102 115	
(7) SCREENS: Well screen installed? Yes N No		115 126	
Manufacturer's Name		126 131	
Type		131 160	
Diam. Slot Size Set from ft. to ft.		160 170	
Diam. Slot Size Set from ft. to ft.		170 175	
December 1		75 202	
WELL TESTS: Drawdown is amount water level is lowered below static level		202 210	
Was a pump test made? Y Yes □ No If yes, by whom? OWner		210 222	
Yield: 600 gal./min. with 80 ft. drawdown after 24 hrs.		222 230	
" " "	clay grey hard 2	230 260	
Air test gal./min. with drill stem at ft. hrs.			
er test gal./min. with ft. drawdown after hrs.			
Artesian flow g.p.m.			
Temperature of water 52° Depth artesian flow encountered ft.	Work started 11/14 19 80 Completed	1/0	
(9) CONSTRUCTION: Special standards: Yes □ No 🖫	Work started 11/14 19 80 Completed Date well drilling machine moved off of well	1/9 19 81 1/9 19 81	
Well seal—Material used	**************************************	<u>1/9 19 81</u>	
Well sealed from land surface to	Drilling Machine Operator's Certification:		
Diameter of well bore to bottom of seal20 in.	This well was constructed under my direct sup and information reported aboye are true to my best	ervision. Materials used	
Diameter of well bore below seal	[Signed] Bob Schele	Date1/9, 19.81.	
Number of sacks of cement used in well seal			
How was cement grout placed?	Drilling Machine Operator's License No	918	
6 gal. water per bag cement	Water Well Contractor's Certification:		
injected down grout hole	. This well was drilled under my jurisdiction as	nd this report is two to	
Was pump installed? Type HP Depth ft.	the best of my knowledge and belief.		
Was a drive shoe used?	Name Bob Scheler Well Drilling		
Did any strata contain unusable water? Yes X No	(Person, firm or corporation) Address 405 N. Burkhart Alban	(Type or print) 1y, Ore. 97321	
Type of Water? depth of strata	0.0.0.0	w.z9+9.4	
Method of sealing strata off	[Signed] Bot Schiller		
Was well gravel packed? ☐ Yes ☐ No Size of gravel:	(Water Well Contractor) Contractor's License No610Date	1/9 - 91	
Gravel placed from	CONTROL O LINCEIDE 140	.:	