

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
MAY 18 1964
STATE ENGINEER

WATER WELL REPORT
(Please type or print)

LINN
14201

15/AW-22

State Well No. _____
State Permit No. _____

(1) OWNER: SALEM, OREGON
Name RICHARD STRODA
Address RT 1 BOX 107
HARRISBURG

(2) LOCATION OF WELL:
County LINN Driller's well number 4466
1/4 Section 22 T. 15 R. 4 W.M.
Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL:
Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED:
6" Diam. from 0 ft. to 35 ft. Gage 1/4
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:
Perforated? Yes No
Type of perforator used _____
Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(8) SCREENS:
Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
Well seal—Material used in seal BENTONITE & CEMENT
Depth of seal 18 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 9 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:
Static level 15 ft. below land surface Date 5-4-64
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? _____
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.

Bailer test 25 gal./min. with 5 ft. drawdown after 1 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 35 ft. Depth of completed well 35 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>Top soil & Clay</u>	<u>0</u>	<u>1</u>
<u>sand & gravel</u>	<u>1</u>	<u>35</u>

Work started 4-29 1964. Completed 5-4 1964
Date well drilling machine moved off of well 5-4 1964

(13) PUMP:
Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME MARK CHRISTENSEN
(Person, firm or corporation) (Type or print)
Address 3550 W 18th Eugene
Drilling Machine Operator's License No. 162 & 9
[Signed] Mark Christensen
(Water Well Contractor)
Contractor's License No. 97 Date 5-12, 1964