

RECEIVED

AUG 31 1965

LINN 14723 G5739

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE ENGINEER STATE OF OREGON SALEM OREGON (Please type or print)

State Well No. 12/2w-24cb State Permit No.

(1) OWNER:

Name F.O. Adkins Address Rt. 1 Box 50D Lebanon Ore.

(2) LOCATION OF WELL:

County Linn Driller's well number 1/4 Section 24 T. 12S R. 2W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Drill Well [x] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [x] Industrial [] Municipal [] Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [x] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

Threaded [] Welded [x] 6" Diam. from 0 ft. to 102 ft. Gage 250

(7) PERFORATIONS:

Perforated? [] Yes [x] No Type of perforator used Size of perforations in. by in.

(8) SCREENS:

Well screen installed? [] Yes [x] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to

(9) CONSTRUCTION:

Well seal-Material used in seal Cement Depth of seal 20 ft. Was a packer used? no Diameter of well bore to bottom of seal 8 in. Were any loose strata cemented off? [] Yes [x] No Depth Was a drive shoe used? [x] Yes [] No Was well gravel packed? [] Yes [x] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [x] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 20-9 ft. below land surface Date 8/17/65 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs.

(12) WELL LOG:

Diameter of well below casing 6 Depth drilled 106 ft. Depth of completed well 106 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Gravel & boulders (0-30), Clay & Gravel (30-90), Brown sand & clay (90-100), Blue rock (100-104), Black sand (104-106).

Work started 8/10 1965 Completed 8-16 1965 Date well drilling machine moved off of well 8-17 1965

(13) PUMP:

Manufacturer's Name Reda Type: Sub. H.P. 3

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Pyle & Salisbury (Person, firm or corporation) (Type or print)

Address 1875 -9th St. Lebanon Ore.

Drilling Machine Operator's License No. 162

[Signed] Ward & Pyle (Water Well Contractor)

Contractor's License No. 216 Date Aug. 18, 1965