

NOTICE TO WATER WELL CONTRACTOR:

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

RECEIVED
 JUN 10 1968
 STATE ENGINEER
 SALEM OREGON

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

6-7330
 LINN
 14733

State Well No. 12/2w-24

State Permit No. _____

(1) OWNER:

Name Harold Bates
 Address Rt. 1, box 122, Lebanon, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
8" Diam. from 0 ft. to 144 ft. Gage .250
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____

Size of perforations in. by in.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
 Type _____ Model No. _____
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 8 ft. below land surface Date 5/10/68

Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.
 " " " " "
 " " " " "

Bailer test 70 gal./min. with 24 ft. drawdown after 2 hrs.

Artesian flow _____ g.p.m. Date _____

Temperature of water _____ Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used grout

Depth of seal 20 ft.

Diameter of well bore to bottom of seal 12 in.

Were any loose strata cemented off? Yes No Depth _____

Was a drive shoe used? Yes No

Did any strata contain unusable water? Yes No

Type of water? _____ depth of strata _____

Method of sealing strata off _____

Was well gravel packed? Yes No Size of gravel: _____

Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County Linn Driller's well number _____
 ¼ ¼ Section 24 T. 12S R. 2W W.M.

Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing 8

Depth drilled 153 ft. Depth of completed well 153 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
top soil and clay	0	10	
cemented sand and gravel	10	25	
sand and gravel	25	55	8'
sand, coarse (brown)	55	65	8'
sand gravel and clay	65	67	
sand, coarse	67	91	8'
sand and gravel	91	105	8'
sand and gravel clay	105	123	8'
clay	123	128	
blue rock (broken)	128	153	8'

Work started 4/27 1968 Completed 5/9 1968

Date well drilling machine moved off of well 5/10 1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Carl Salishbury Date 6/5, 1968
 (Drilling Machine Operator)

Drilling Machine Operator's License No. 162

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Pyle and Salishbury (Type or print)

Address 1875 9th St., Lebanon, Oregon

[Signed] Ward E. Pyle (Water Well Contractor)

Contractor's License No. 216 Date 6/5, 1968