NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

RECEIVED JUN - 5 1970 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

LINN 1474

G-4773

State Well No. 12/2W-24

State Permit No. .....

(1) OWNER:
Name Edd Page
Address 4770 South Santiam Highway Lebanon Oregon

(2) TYPE OF WORK (check):
New Well ☐ Deepening ☒ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
8" Diam. from 0 ft. to 205 ft. Gage 250
..." Diam. from ... ft. to ... ft. Gage ...
..." Diam. from ... ft. to ... ft. Gage ...

(6) PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used an acetylene torch
Size of perforations 1/4 in. by 6 in.
120 perforations from 170 ft. to 205 ft.
37 perforations from 40 ft. to 45 ft.
... perforations from ... ft. to ... ft.
... perforations from ... ft. to ... ft.
... perforations from ... ft. to ... ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name ...
Type ... Model No. ...
Diam. ... Slot size ... Set from ... ft. to ... ft.
Diam. ... Slot size ... Set from ... ft. to ... ft.

(8) WATER LEVEL: Completed well.
Static level 18 ft. below land surface Date 5-7-70
Artesian pressure lbs. per square inch Date

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☐ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
" " "
Bailer test 40 gal./min. with 42 ft. drawdown after 2 hrs.
Artesian flow g.p.m. Date
Temperature of water 54° Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:
Well seal—Material used used existing seal
Depth of seal 18 in 33" Well ft.
Diameter of well bore to bottom of seal 45 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth ...
Was a drive shoe used? ☒ Yes ☐ No
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel: ...
Gravel placed from ... ft. to ... ft.

(11) LOCATION OF WELL:
County LINN Driller's well number
1/4 1/4 Section 24 T. 12-S R. 2-W W.M.
Bearing and distance from section or subdivision corner 168' west of and in line with B.P.A. Power marker bar Vg L 297-459 South off Access Road Box 379

(12) WELL LOG: Diameter of well below casing 8
Depth drilled 159 ft. Depth of completed well 205 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Sand + Clay yellow Hard	46	190	
Clay Blue	190	200	
Black Sand + gravel	200	205	
Drilled 8" in 8" of 33" Bored well			
Card sent in his mother name			

Work started 10-18 19 69 Completed 5-7 19 70
Date well drilling machine moved off of well 5-7 19

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Lemon A. White (Drilling Machine Operator) Date ..., 19...
Drilling Machine Operator's License No. 554

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME BOB'S WELL DRILLING (Person, firm or corporation) (Type or print)
Address 465 Wagoner Sheldon Lebanon Ore
[Signed] Robert E. White (Water Well Contractor)
Contractor's License No. 121 Date 6-4, 1970

(USE ADDITIONAL SHEETS IF NECESSARY)