NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
JUN 3 1968
STATE ENGINEER
SALEM, OREGON

# WATER WELL REPORT
## STATE OF OREGON
(Please type or print)
(Do not write above this line)

LINN
2719

State Well No. 9/1w-15 K
State Permit No.

**(1) OWNER:**
Name Mr. Richard Nienke
Address Rte.1, Box 24, Stayton

**(2) TYPE OF WORK (check):**
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

**(4) PROPOSED USE (check):**
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

**CASING INSTALLED:** Threaded ☐ Welded ☒
8" Diam. from 0 ft. to 37 ft. Gage .270
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

**PERFORATIONS:** Perforated? ☒ Yes ☐ No.
Type of perforator used Mills
Size of perforations 1/4 in. by 2 in.
200 perforations from 37 ft. to 20 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

**(7) SCREENS:** Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

**(8) WATER LEVEL: Completed well.**
Static level 12 ft. below land surface Date 5/7/68
Artesian pressure lbs. per square inch Date

**(9) WELL TESTS:** Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? Self
Yield: 200 gal./min. with 3 ft. drawdown after 1 hrs.
" " "
" " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☒ No

**(10) CONSTRUCTION:**
Well seal—Material used Bentonite
Depth of seal Drilled in 20 ft.
Diameter of well bore to bottom of seal 8 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☒ Yes ☐ No
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

**(11) LOCATION OF WELL:**
County Linn Driller's well number 300
NW ¼ SE ¼ Section 15 T. 9S R. 1W W.M.
Bearing and distance from section or subdivision corner

**(12) WELL LOG:** Diameter of well below casing 6
Depth drilled 37 ft. Depth of completed well 37 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

| MATERIAL | From | To | SWL |
|---|---|---|---|
| Top soil | 0' | 2' | |
| Cobbles & gravel (large) | 2' | 15' | |
| Cobbles-gravel-(cemented) | 15' | 22' | |
| Silted gravel-sand w.b. | 22' | 23' | 12' |
| Cement gravel-cobbles | 23' | 27' | |
| Gravel & cobbles (packed) w.b. | 27' | 37' | 12' |

Work started 5/6/68 19 Completed 5/7/68 19
Date well drilling machine moved off of well 5/7/68 19

**Drilling Machine Operator's Certification:**
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] T. J. Tolmasoff (Drilling Machine Operator) Date 5/13/68, 19
Drilling Machine Operator's License No. 320

**Water Well Contractor's Certification:**
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Pete Tolmasoff Well Drilling
(Person, firm or corporation) (Type or print)
Address Turner, Ore.
[Signed] Pete J. Tolmasoff (Water Well Contractor)
Contractor's License No. 410 Date 5/13/68, 19

(USE ADDITIONAL SHEETS IF NECESSARY)