

RECEIVED
OCT 9 1959

WATER WELL REPORT

Lin 2737

9/1W-15K

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

STATE ENGINEER

STATE OF OREGON G1572

State Well No.

State Permit No. G1434

(1) OWNER: DeWitt, Oregon
Name: Jack Tiger
Address: P.O. Box 24 Stanton Oregon

(2) LOCATION OF WELL:
County: Linn
Owner's number, if any: ...
Bearing and distance from section or subdivision corner: ...

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:
Threaded Welded
8" Diam. from 0 ft. to 18 ft. Gage 280

(7) PERFORATIONS:
Perforated? Yes No
Type of perforator used: Cutting torch
SIZE of perforations: 1/2 in. by 6 in.
45 perforations from 7 ft. to 18 ft.

(8) SCREENS:
Well screen installed Yes No
Manufacturer's Name: ...
Type: ... Model No. ...
Slot size: ... Set from ... ft. to ... ft.

(9) CONSTRUCTION:
Was well gravel packed? Yes No Size of gravel: ...
Gravel placed from ... ft. to ... ft.
Was a surface seal provided? Yes No To what depth? ... ft.
Material used in seal: ...
Did any strata contain unusable water? Yes No
Type of water? ... Depth of strata ...
Method of sealing strata off: ...

(10) WATER LEVELS:
Static level: 9 ft. below land surface Date: 9/25/59
Artesian pressure: ... lbs. per square inch Date: ...
Log Accepted by: DeWitt Tiger
[Signed] DeWitt Tiger Date: Sept 30, 1959

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? -
Yield: gal./min. with ft. drawdown after hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:
Diameter of well: 8 inches.
Depth drilled: 18 ft. Depth of completed well: 18 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Sandy topsoil	0	1
Unconsolidated sand and gravels to boulder size	1	15'6"
Cemented gravel	15'6"	18

Work started 9/25 1959 Completed 9/26 1959

(13) PUMP:
Manufacturer's Name: ...
Type: ... H.P. ...

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME: WEST WELL DRILLING (Person, firm, or corporation)
Address: 4098 MARKET ST. N.E., SALEM
Driller's well number: ...
[Signed] Marion E. West (Well Driller)
License No. 30 Date: 9/30, 1959