

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT, *Linn*
SALEM, OREGON 97310
within 30 days from the date
of well completion. *3113*

WATER WELL REPORT

RECEIVED

STATE OF OREGON
(Please type or print)

State Well No. *95/2N-3500*
DEC 21 1977

(Do not write above this line)

State Permit No. _____
WATER RESOURCES DEPT.
SALEM, OREGON

(1) OWNER:

Name Rob Miller
Address P.O. Box 496
Stayton, Oregon 97383

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
10 " Diam. from 0 ft. to 520 ft. Gage .250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used Torch
Size of perforations 3/16 in. by 6 in.
400 perforations from 414 ft. to 520 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " " " "
" " " " " "
AIR
INDEX test 200 gal./min. with 480 ft. drawdown after 4 hrs.
Artesian flow _____ g.p.m.
Temperature of water 53 Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 25 ft.
Diameter of well bore to bottom of seal 14 in.
Diameter of well bore below seal 10 in.
Number of sacks of cement used in well seal 15 sacks
How was cement grout placed?
hand mixed and hand placed

Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: 3/8 Pea
Gravel placed from 25 ft. to 520 ft.

(10) LOCATION OF WELL:

County Linn Driller's well number 1401177G
SW 1/4 SW 1/4 Section 35 T. 9S R. 2W W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 449 ft.
Static level 25 ft. below land surface. Date 11/20/77
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 10

Depth drilled 561 ft. Depth of completed well 561 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Rocky Top Soil	0	2	
Brown Clay & Gravel	2	10	
Brown Clay	10	21	
Sticky Gray Clay	21	46	25
Gray Claystone	46	53	
Claystone & Gravel	53	55	
Gray Claystone	55	62	
Sticky Gray Clay	62	117	
Green Clay	117	128	
Gray Claystone	128	146	
Firm Gray Claystone	146	188	
Fine Gray Sandstone	188	248	
Sandy Gray Claystone	248	403	
Brown Claystone	403	411	
Light Gray Claystone	411	429	
Light Gray Sand Rock	429	432	
Light Gray Sandstone	432	448	
Gray Sandstone W/Strreaks of	448		
Brown Sandstone		561	

Work started 8/22 1977 Completed 11/23 1977
Date well drilling machine moved off of well 11/23 1977

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] George M. Simpson Date 11/29, 1977
Drilling Machine Operator

Drilling Machine Operator's License No. 1072

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Schoen Electric Inc.
(Person, firm or corporation) (Type or print)

Address 626 W. Queen Albany, Oregon 97321

[Signed] Danny E. Schoen
(Water Well Contractor)

Contractor's License No. 513 Date 11/30, 1977