

NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date
of well completion.

RECEIVED
JUN 8 1968

WATER WELL REPORT

STATE ENGINEER

STATE OF OREGON

(Please type or print)

SALEM, OREGON

(Do not write above this line)

State Well No. 9/1-27 dd

State Permit No.

(1) OWNER:

Name Earl B. Martin

Address Rt. 1, Seaside, Oregon

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐Cable ☒ Jetted ☐Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:

Threaded ☐ Welded ☒

8" Diam. from 0 ft. to 30 ft. Gage 220

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No

Type of perforator used

Size of perforations in, by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 14 ft. below land surface Date Feb. 15, 1968

Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Bailer test 3.5 gal./min. with 24 ft. drawdown after 1 hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(10) CONSTRUCTION:

Well seal—Material used Cement

Depth of seal 20 ft.

Diameter of well bore to bottom of seal 12 in.

Were any loose strata cemented off? ☐ Yes ☒ No DepthWas a drive shoe used? ☐ Yes ☒ NoDid any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Linn Driller's well number 287-

1/4 1/4 Section 27 T. 9S R. 1E W.M.

Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 8

Depth drilled 145 ft. Depth of completed well 145 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Soil	0	2	
Boulders & Clay	2	10	
Claystone Soft Yellow	10	18	
Claystone Hard	18	70	30
Sandstone	70	80	20
Claystone Hard	80	100	20
Sandstone	100	140	14
Rock Med Hard	140	145	14

Work started Feb 10 1968 Completed Feb 15 1968

Date well drilling machine moved off of well Feb. 15 1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] William P. Long Date Feb. 15, 1968.
(Drilling Machine Operator)

Drilling Machine Operator's License No. 117

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Long Drilling
(Person, firm or corporation) (Type or print)

Address 4120 Fletcher Rd. N.E. Salem, Oregon

[Signed] William P. Long
(Water Well Contractor)

Contractor's License No. 75 Date Feb. 15, 1968