

JUN 9 1982

State Well No.

10s | 1w - 25bb

State Permit No.

(10) LOCATION OF WELL:

Name John Duncan
Address 43458 Roger Mt. Loop
City Scio State OR

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Rotary Air	☒	Driven	☐	Domestic	☒	Industrial	☐	Municipal	☐
Rotary Mud	☐	Dug	☐	Irrigation	☐	Test Well	☐	Other	☐
	☐	Bored	☐	Thermal:		Withdrawal	☐	Reinjection	☐

Steel ☒ Plastic ☒
Threaded ☐ Welded ☒

6 " Diam. from +1 ft. to 71 ft. Gauge ☐ threaded ☒ welded .250
" Diam. from ft. to ft. Gauge

4" Diam. from 57 ft. to 225 ft. Gauge Class 160

Perforated? ☒ Yes ☐ No

Type of perforator used			
Size of perforations	in. by	in.	
30	perforations from	145. ft. to	165. ft.
60	perforations from	185. ft. to	225. ft.
	perforations from	ft. to	ft.

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot Size Set from ft. to ft.

Diam. Slot Size Set from ft. to ft.

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom? _____
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 " " " "
 Air test 45 _____ gal./min. with drill stem at 225 ft. 1 _____ hrs.
 Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow _____ g.p.m.
 Temperature of water 54 _____ Depth artesian flow encountered _____ ft.

Special standards: Yes ☐ No ☒

Well seal—Material used Cement
Well sealed from land surface to 40 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 18 sacks
How was cement grout placed? From Bottom To Top

Was pump installed? NO Type HP Depth ft.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

County Linn Driller's well number
NW ¼ NW ¼ Section 25 T. 10S R. 1W W.M.
Tax Lot # Lot Blk Subdivision
Address at well location: 43458 Roger Mt. Loop, Scio, OR

Depth at which water was first found	155	ft.
Static level	65	ft. below land surface. Date 6/8/82
Artesian pressure		lbs. per square inch. Date

Diameter of well below casing 6"

Depth drilled 225 ft. Depth of completed well 618 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

[illegible]

Work started	6/7	19 82	Completed	6/8	19 82
Date well drilling machine moved off of well				6/8/	19 82

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] George M. Simpson Date 6/18, 1982
(Drilling Machine Operator)

Drilling Machine Operator's License No. 1072

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Schoen Electric, Inc.
(Person, firm or corporation) (Type or print)

Address 626 W. Queen Ave. Albany, OR (Type or print)
[Signed] Sam E. Abou
(Water Well Contractor)
Contractor's License No. 513 Date 6/8 1982

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

SP*12658-690