

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

RECEIVED

MAY 29 1966

WATER WELL REPORT

Linn
3400

9/2-27
~~20~~

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion

STATE OF OREGON
ENGINEER (Please type or print)
SALEM, OREGON

State Well No.
State Permit No.

(1) OWNER:

Name North Santiam Plywood Company
Address Lyons, Oregon

(2) LOCATION OF WELL:

County Linn Driller's well number
1/4 Section S, E. 20 T. 9, S R. 2, E W.M.
Bearing and distance from section or subdivision corner

WELL NO. 1

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Rotary Driven
Irrigation Test Well Other Cable Jetted
Dug Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED:

Threaded Welded
.....12....." Diam. from21..... ft. to94..... ft. Gage250
....." Diam. from ft. to ft. Gage
....." Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used Mills Perforator
Size of perforations 3/8 in. by 2 1/2 in.
.....50..... perforations from35..... ft. to40..... ft.
.....160..... perforations from43..... ft. to58..... ft.
.....60..... perforations from86..... ft. to90..... ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name Model No.
..... Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Drill Cuttings & Bentonite
Depth of seal20..... ft. Was a packer used? No
Diameter of well bore to bottom of seal16..... in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 15 ft. below land surface Date 3-22-66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Stettler
Yield: 120 gal./min. with 85 ft. drawdown after 4 hrs.
" " " " " "
" " " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing12.....

Depth drilled 250 ft. Depth of completed well 250 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

| MATERIAL | FROM | TO |
|-----------------------------|------|-----|
| Brown Clay | 0 | 6 |
| Brown Clay with some gravel | 6 | 18 |
| Medium Gravel | 18 | 21 |
| Course Gravel | 21 | 23 |
| Medium Gravel | 23 | 40 |
| Brown Clay | 40 | 43 |
| Course Sand | 43 | 45 |
| Medium Gravel and Sand | 45 | 52 |
| Blue Clay | 52 | 55 |
| Medium Gravel and Sand | 55 | 58 |
| Blue Clay | 58 | 65 |
| Brown Tuff Stone | 65 | 86 |
| Medium Gravel and Sand | 86 | 90 |
| Blue Clay Stone | 90 | 181 |
| Brown Tuff Stone | 181 | 252 |

Work started 3-1-66 19 Completed 3-22-66 19
Date well drilling machine moved off of well 3-26-66 19

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME MILLER - ROBINSON - WEST
(Person, firm or corporation) (Type or print)
Address 5545 Joseph St. S.E. Salem, Oregon

Drilling Machine Operator's License No. 59

[Signed] Harold B. Miller
(Water Well Contractor)

Contractor's License No. 37 Date 3-23-66, 19.....