

OBSERVATION WELL

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED MAY 26 1966

WATER WELL REPORT

2177 3403

27 9/2-30

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion

STATE OF OREGON (Please type or print)

State Well No. 9/2-30

State Permit No. G-3891

(1) OWNER:

Name North Santiam Plywood Company Address Lyons, Oregon

(2) LOCATION OF WELL:

County LINN Driller's well number 1/4 Section S.E. 20T. 9, S R. 2, E W.M. Bearing and distance from section or subdivision corner Well # 2

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon [] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Rotary [] Driven [] Irrigation [X] Test Well [] Other [] Cable [X] Jetted [] Dug [] Bored []

(5) TYPE OF WELL:

(6) CASING INSTALLED:

12" Diam. from +1 ft. to 189 ft. Gage .250

(7) PERFORATIONS:

Perforated? [X] Yes [] No Type of perforator used Mills Perforator Size of perforations 3/8 in. by 2 1/2 in. 390 perforations from 36 ft. to 80 ft. 220 perforations from 91 ft. to 115 ft. 160 perforations from 169 ft. to 182 ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Drill Cuttings & Bentonite Depth of seal 25 ft. Was a packer used? NO Diameter of well bore to bottom of seal 15 in. Were any loose strata cemented off? [] Yes [X] No Depth Was a drive shoe used? [X] Yes [] No Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [X] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 46 ft. below land surface Date 4-18-66 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [] No If yes, by whom? Stettler Yield: 500 gal./min. with 7 1/4 ft. drawdown after 10 hrs.

(12) WELL LOG:

Diameter of well below casing 12 Depth drilled 194 ft. Depth of completed well 192 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Soil, Medium Gravel and Clay, Medium Gravel, Sand and Gravel, etc.

Work started 4-1-66 19 Completed 4-18-66 19 Date well drilling machine moved off of well 4-18-66 19

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME MILLER - ROBINSON - WEST (Person, firm or corporation) (Type or print) Address 5545 Joseph St. S.E. Salem, Oregon

Drilling Machine Operator's License No. 59 [Signed] (Water Well Contractor) Contractor's License No. 37 Date 4-20-66 19