

RECEIVED

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

AUG 28 1962 WATER WELL REPORT

STATE OF OREGON (Please type or print) SALEM, OREGON

Linn 3444

9/2-36A

State Well No. State Permit No.

(1) OWNER:

Name Frank Lumber Co. Address Mill City, Oregon

(2) LOCATION OF WELL:

County Linn Driller's well number 9/2-36A Section T. R. W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Deepening [] Reconditioning [] Abandon []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

10 3/4" Diam. from 1.0 ft. to 149 ft. Gage .250

(7) PERFORATIONS:

Perforated? [x] Yes [] No Type of perforator used Mills Size of perforations 3/8 in. by 2 1/2 in. 180 perforations from 80 ft. to 120 ft. 200 perforations from 135 ft. to 148 ft.

(8) SCREENS:

Well screen installed [] Yes [x] No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite Depth of seal 80 ft. Was a packer used? no Diameter of well bore to bottom of seal 11 1/2 in. Were any loose strata cemented off? [] Yes [x] No Depth Was a drive shoe used? [x] Yes [] No Was well gravel packed? [] Yes [x] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 67 ft. below land surface Date 8/14/62 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [x] Yes [] No Yield: 400 gal./min. with 73 ft. drawdown after 4 1/2 hrs. Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [] Yes [] No

(12) WELL LOG:

Diameter of well below casing Depth drilled 150 ft. Depth of completed well 150 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows: Coarse gravel & boulders (0-121), Brwn silt (121-132), Coarse gravel & boulders (132-150)

After drilling to 81 ft static stood at 67 ft. Shot large boulder at 78 ft with 13 sticks of 60% dynamite

Work started 7/25 19 62 Completed 8/15/62 19 Date well drilling machine moved off of well 19

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Harry A. Robinson (Person, firm or corporation) (Type or print)

Address 2214 Front St. NE Salem, Ore.

Drilling Machine Operator's License No. 63

[Signed] Harry A. Robinson (Water Well Contractor)

Contractor's License No. 22 Date 8/27/62, 19