NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED JUN 17 1970 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED JUN 22 1970 STATE ENGINEER SALEM, OREGON

3477 Linn

State Well No. 9/3-31

State Permit No.

(1) OWNER:
Name Arey Podrabski
Address Mill City, Ore.

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:
Threaded ☐ Welded ☒
6 5/8" Diam. from 1/2 ft. to 76 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:
Perforated? ☒ Yes ☐ No.
Type of perforator used Mills
Size of perforations 5/16 in. by 2 in.
28 perforations from 58 ft. to 70 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.
Static level 75 ft. below land surface Date 6/9/70
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
" " "
Bailer test 1/2 gal./min. with 82 ft. drawdown after 1 1/2 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(10) CONSTRUCTION:
Well seal—Material used Cement grout
Depth of seal 54 ft.
Diameter of well bore to bottom of seal 8 in.
Were any loose strata cemented off? ☐ Yes ☐ No Depth
Was a drive shoe used? ☒ Yes ☐ No
Did any strata contain unusable water? ☒ Yes ☐ No
Type of water? Surface depth of strata
Method of sealing strata off Cement?
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:
County Linn Driller's well number 9/3-31-E
¼ ¼ Section T. R. W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:
Diameter of well below casing 6
Depth drilled 176 ft. Depth of completed well 176 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Silt	0	5	
Coarse gravel & boulders	5	70	
Basalt?	70	87	
Red shale	87	94	
Basalt ?	94	108	
Tuffs	108	176	

Work started 5/27 1970 Completed 6/9/70 19
Date well drilling machine moved off of well 6/9/70 19

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Harry A Robinson Date June 16, 1970
(Drilling Machine Operator)
Drilling Machine Operator's License No. 63

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Harry A. Robinson
(Person, firm or corporation) (Type or print)
Address 2214 Front St NE Salem, Ore.
[Signed] Harry A Robinson
(Water Well Contractor)
Contractor's License No. 22 Date 6/16/70, 19

(USE ADDITIONAL SHEETS IF NECESSARY)