

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER WELL REPORT

STATE OF OREGON

(Please type or print) Do not write above this line

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED MAY 5 1970

Linn 9/3-32bd State Well No. 3496 State Permit No. G 5379 Well #1

(1) OWNER: STATE ENGINEER SALEM, OREGON

Name Dan Walker Address Rt. 1 Mill City, Oregon

(11) LOCATION OF WELL:

County Linn Driller's well number 362 1/4 Section 32 T. 9S R. 3E W.M. Bearing and distance from section or subdivision corner

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other []

(12) WELL LOG:

Diameter of well below casing Depth drilled 160 ft. Depth of completed well 160 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows include Soil, Gravel Boulders Clay, Mad Gravel Clay, Boulders Gravel, Boulders, Clay Silt, Gravel, Clay Silt Small Gravel, Gravel, Clay.

(6) CASING INSTALLED:

Threaded [] Welded [X] 10" Diam. from 0 ft. to 160 ft. Gage 250

(7) PERFORATIONS:

Perforated? [X] Yes [] No Type of perforator used Oxy Acet. & Milk knife Size of perforations 1/2 in. by 8 in. 20 perforations from 74 ft. to 84 ft. 100 perforations from 140 ft. to 160 ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 49 ft. below land surface Date May 1, 1970 Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [] No If yes, by whom? Miller-West Yield: 250 gal./min. with 189 ft. drawdown after 4 hrs. Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [] Yes [X] No

(10) CONSTRUCTION:

Well seal—Material used Cement Depth of seal 20 ft. Diameter of well bore to bottom of seal 16 in. Were any loose strata cemented off? [] Yes [X] No Depth Was a drive shoe used? [X] Yes [] No Did any strata contain unusable water? [] Yes [X] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft.

Work started March 30 1970 Completed April 24 1970

Date well drilling machine moved off of well May 1 1970

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] William E. Long Date May 1, 1970 (Drilling Machine Operator)

Drilling Machine Operator's License No. 117

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Long Drilling (Person, firm or corporation) (Type or print)

Address 4190 Flataban Rd N.E. Salem, Ore.

[Signed] William E. Long (Water Well Contractor)

Contractor's License No. 75 Date May 1, 1970