NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED JUN 16 1969 STATE ENGINEER SALEM OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

Linn 3690

State Well No. 10/1W-10 bc

State Permit No.

(1) OWNER:

Name Elmer F. Williams

Address 862 Horizon Ct. N.
Salem, Ore.

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒

6 5/8" Diam. from 1/2 ft. to 18 1/2 ft. Gage .250

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☐ Yes ☒ No.

Type of perforator used

Size of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 32 ft. below land surface Date 6/6/69

Artesian pressure lbs. per square inch Date

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " "

" " "

Bailer test 18 gal./min. with 52 ft. drawdown after 1 hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(10) CONSTRUCTION:

Well seal—Material used Drill cuttings & clay

Depth of seal 18 ft.

Diameter of well bore to bottom of seal 9 in.

Were any loose strata cemented off? ☐ Yes ☒ No Depth

Was a drive shoe used? ☒ Yes ☐ No

Did any strata contain unusable water? ☐ Yes ☐ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Linn Driller's well number 10/1W-10E

¼ ¼ Section T. R. W.M.

Bearing and distance from section or subdivision corner

(12) WELL LOG: Diameter of well below casing 6

Depth drilled 100 ft. Depth of completed well 100 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Clay & cobble stones	0	8	
Tuffs (tan)	8	13	
Tuffs (grey)	13	35	
Tuffs (brwn)	35	37	
Tuffs (grey)	37	77	
Shale or tuffs dark grey fine grain	77	80	
Tuffs (grey)	80	100	

Work started 6/3 1969 Completed 6/6/69 19

Date well drilling machine moved off of well 6/6/69 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Harry A. Robinson Date 6-14, 1969
(Drilling Machine Operator)

Drilling Machine Operator's License No. 63

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Harry A. Robinson
(Person, firm or corporation) (Type or print)

Address 2214 Front St NE Salem, Ore.

[Signed] Harry A. Robinson
(Water Well Contractor)

Contractor's License No. 22 Date 6/14/69, 19

(USE ADDITIONAL SHEETS IF NECESSARY)