NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

OK

Linn 3782

RECEIVED

WATER WELL REPORT

STATE OF OREGON AUG 16 1974 State Well No. 10S/1W-16 bd

(Please type or print) STATE ENGINEER State Permit No.

(Do not write above this line) SALEM, OREGON

(1) OWNER:

Name Robert Wade

Address Rt 1, Box 198

Scio, Oregon 97374

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [] Driven []
Cable [X] Jetted []
Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal []
Irrigation [] Test Well [] Other []

CASING INSTALLED:

Threaded [] Welded [X]

6 " Diam. from 0 ft. to 74 ft. Gage .250

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? [] Yes [X] No.

Type of perforator used

Size of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [] Yes [X] No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Bailer test 20 gal./min. with 250 ft. drawdown after 2 hrs.

Artesian flow g.p.m.

Temperature of water 50 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement

Well sealed from land surface to 37 ft.

Diameter of well bore to bottom of seal 10 in.

Diameter of well bore below seal 6 in.

Number of sacks of cement used in well seal 14 sacks

Number of sacks of bentonite used in well seal sacks

Brand name of bentonite

Number of pounds of bentonite per 100 gallons of water lbs./100 gals.

Was a drive shoe used? [X] Yes [] No Plugs Size: location ft.

Did any strata contain unusable water? [] Yes [X] No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? [] Yes [X] No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Linn Driller's well number 106874P

SE ¼ NW ¼ Section 16 T. 10S R. 1W W.M.

Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 12 ft.

Static level 12 ft. below land surface. Date 8-12-74

Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 450 ft. Depth of completed well 450 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Sandy Topsoil	0	2	
Cobbles & gravel	2	13	12'
Red clay	13	32	
light green clay	32	37	
grey clay	37	41	
red clay	41	57	
soft blue sand rock	57	73	
sand rock (blue)	73	450	

Work started 7-27-74 19 Completed 8-12-74 19

Date well drilling machine moved off of well 8-12-74 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Nat Tudors (Drilling Machine Operator) Date Aug 15, 19 74

Drilling Machine Operator's License No. 898

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Schoen Electric & Pump (Person, firm or corporation) (Type or print)

Address 626 W. Queen Ave. Albany, Or. 97321

[Signed] Lenny E Schoen (Water Well Contractor)

Contractor's License No. 513 Date 8/15, 19 74

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119