**WATER WELL REPORT**
**STATE OF OREGON**

Linn 385

RECEIVED
JUN 25 1982
WATER RESOURCES DEPT
SALEM, OREGON

State Well No. 10S/3W-16aa

State Permit No. .....

## (1) OWNER:

Name Sullivan Construction
Address 1040 Old Salem Road
City Albany State OR

## (2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

## (3) TYPE OF WELL:

| | | |
|---|---|---|
| Rotary Air | ☒ | Driven ☐ |
| Rotary Mud | ☐ | Dug ☐ |
| Cable | ☐ | Bored ☐ |

## (4) PROPOSED USE (check):

| | | | | | |
|---|---|---|---|---|---|
| Domestic | ☐ | Industrial | ☒ | Municipal | ☐ |
| Irrigation | ☐ | Test Well | ☐ | Other | ☐ |
| Thermal: | | Withdrawal | ☐ | Reinjection | ☐ |

## (5) CASING INSTALLED:

Steel ☒ Threaded ☐ Plastic ☐ Welded ☒

6" Diam. from +2 ft. to 91 ft. Gauge .250
" Diam. from ft. to ft. Gauge

## LINER INSTALLED:

" Diam. from ft. to ft. Gauge

## (6) PERFORATIONS:

Perforated? ☐ Yes ☒ No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

## (7) SCREENS:

Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

## (8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
Air test 20 gal./min. with drill stem at 140 ft. 1 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 53 Depth artesian flow encountered ft.

## (9) CONSTRUCTION:

Special standards: Yes ☐ No ☒
Well seal—Material used cement
Well sealed from land surface to 21 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 15 sacks
How was cement grout placed? From bottom to top

Was pump installed? No Type HP Depth ft.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

## (10) LOCATION OF WELL:

County Linn Driller's well number
NE ¼ NE ¼ Section 16 T. 10S R. 3W W.M.
Tax Lot # Lot Blk Subdivision
Address at well location: at intersection of Old Salem Road & I-5 ( Albany, OR)

## (11) WATER LEVEL: Completed well.

Depth at which water was first found 110 ft.
Static level 16 ft. below land surface. Date 6/22/82
Artesian pressure lbs. per square inch. Date

## (12) WELL LOG:

Diameter of well below casing 6"
Depth drilled 140 ft. Depth of completed well 140 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

| MATERIAL | From | To | SWL |
|---|---|---|---|
| Large gravel & med. sand | 0 | 8 | |
| Brown sandy clay | 8 | 11 | |
| Large gravel & med. sand (cemented) | 11 | 13 | |
| Brown sticky clay | 13 | 15 | |
| Large gravel & med. sand (cemented) | 15 | 38 | |
| Gray clay | 38 | 76 | |
| Gray sandy clay | 76 | 87 | |
| Gray clay stone | 87 | 100 | |
| Gray sandstone | 100 | 140 | |

Work started 6/18 1982 Completed 6/22 1982
Date well drilling machine moved off of well 6/22 1982

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] George M. Simpson (Drilling Machine Operator) Date 6/24, 1982

Drilling Machine Operator's License No. 1072

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Schoen Electric, Inc. (Person, firm or corporation) (Type or print)
Address 626 W. Queen Ave., Albany, OR 97321

[Signed] Larry R. Schoen (Water Well Contractor)

Contractor's License No. 513 Date 6/24, 1982

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*12658-690