

NC LINN 4467

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED WATER WELL REPORT STATE OF OREGON JUN 20 1967

State Well No. 10/3w-4cab State Permit No.

G5942

STATE ENGINEER SALEM, OREGON

(1) OWNER:

Name Dee S. Chambers Address Rt. 2, Box 184 Albany, Oregon

(2) LOCATION OF WELL:

County Linn Driller's well number 1/4 1/4 Section 4 T. 10S R. 3W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

8" Diam. from 0 ft. to 31 ft. Gage 1/4 Wall

(7) PERFORATIONS:

Perforated? [X] Yes [] No Type of perforator used Acetylene Torch Size of perforations 1/2 in. by 12 in. 38 perforations from 21 ft. to 32 ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite Depth of seal 18 ft. Was a packer used? Diameter of well bore to bottom of seal 12 in. Were any loose strata cemented off? [] Yes [X] No Depth Was a drive shoe used? [X] Yes [] No Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [X] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 12 ft. below land surface Date 5-11-67 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [] No If yes, by whom? Self Yield: 400 gal./min. with NO ft. drawdown after 1 hrs.

(12) WELL LOG:

Diameter of well below casing 8" Depth drilled 33 ft. Depth of completed well 33 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with 3 columns: MATERIAL, FROM, TO. Rows: Top Soil (0-2), Sandy Loam (2-12), Sand & Gravel (12-32), Blue Clay (32-33).

Work started 5-9 19 67 Completed 5-11 19 67 Date well drilling machine moved off of well 5-11 19 67

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Merle Warren Well Drilling (Person, firm or corporation) (Type or print)

Address Rt. 1, Box 85, Tangent, Oregon

Drilling Machine Operator's License No. 313

[Signed] Merle Warren (Water Well Contractor)

Contractor's License No. 182 Date 5/15-1967