LINN
4527

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON

State Well No. 10/3W-5K

State Permit No.

(1) OWNER:
Name Jack Pesheck
Address RT #2 Albany Oregon

(2) LOCATION OF WELL:
County LINN Owner's number, if any—
NW ¼ SE ¼ Section 5 T. 10-S R. 3-W
Bearing and distance from section or subdivision corner
S. 76° 15' W. 23.5 CHAINS FROM NE CORNER OF SE ¼, S. 5, T. 10 S., R. 3 W.

(3) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☐
6" Diam. from +1' ft. to 25' ft. Gage 22.5
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? ☒ Yes ☐ No
Type of perforator used
SIZE of perforations 1/2" in. by 8 in.
35 perforations from 21 ft. to 24 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed ☐ Yes ☐ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Was well gravel packed? ☐ Yes ☐ No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? ☐ Yes ☐ No To what depth? ft.
Material used in seal—
Did any strata contain unusable water? ☐ Yes ☐ No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 14 ft. below land surface Date 8-26-59
Artesian pressure lbs. per square inch Date

Log Accepted by:
[Signed] Jack Pesheck (Owner) Date Aug 26, 1959

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? Mr Pesheck
Yield: 200 gal./min. with 8" drawdown after hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 57 Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG: Diameter of well 6 inches.
Depth drilled 25' ft. Depth of completed well 25' ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Sandy Loam	Top	6
" Clay	6	9
Sand	9	12
Sand & Gravel	12	19
Large Gravel	19	22
Small "	22	25

Work started 8-26 1959 Completed 8-26 1959

(13) PUMP:
Manufacturer's Name
Type: CENTRIFUGAL H.P. 5

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Bill Hamilton Drilling Co (Person, firm, or corporation) (Type or print)
Address 838 E 3rd Ave Albany
Driller's well number #2
[Signed] Bill Hamilton (Well Driller)
License No. 52 Date 8-26, 1959

(USE ADDITIONAL SHEETS IF NECESSARY)