The original and first copy () V : 30 1967 WATER WELL REPO of this report are to be filed with the ATE ENGINEER STATE OF OREGON 97310 ON (Please type or print)

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

(Please type or print)
(Do not write above this line)

State Well No. 10 State Permit No.

(1) OWNER:	(11) LOCATION OF WELL:
Name Ammon Bros.	County Linn Driller's well number
Address Rt. 2, Box 258, Albany, Oregon	14 14 Section 6 T. 10S R. 3W W.M.
	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	
New Well Deepening □ Reconditioning □ Abandon □	
If abandonment, describe material and procedure in Item 12.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(12) WELL LOG: Diameter of well below casing
Rotary Driven Domestic Industrial Municipal Domestic	Depth drilled 31 ft. Depth of completed well 31 ft.
Cable X Jetted Domeste Industrial Municipal Dug Bored Irrigation K Test Well Other	Formation: Describe color, texture, grain size and structure of materials;
CASING INSTALLED: Threaded □ Welded ₩	and show thickness and nature of each stratum and aquifer penetrated,
10 "Diam. from +9" X to 31 ft. Gage 250 Wal	with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.
" Diam, from ft. to ft. Gage	MATERIAL From To SWL
	Top Soil 0 10
	Coarse Gravel 10 23 .
PERFORATIONS: Perforated? M Yes No.	Sand & Gravel 23 31
Type of perforator used Acetylene Torch	- Sand a draver - Ly yr
Size of perforations ½ in. by 12 in.	
48 perforations from 18 ft. to 30 ft.	
perforations from ft. to ft.	
perforations from ft. to ft.	
perforations from ft. to ft.	
perforations from ft. to ft.	
(7) SCREENS: Well screen installed? ☐ Yes 🕅 No	
Manufacturer's Name	
Type Model No.	
Diam. Slot size from ft. to ft.	
Diam. Slot size Set from ft. to ft.	
(O) MARIED LEVEL Commission II	
(8) WATER LEVEL: Completed well.	
Static level 12 ft. below land surface Date 11-28-6	
Amesian pressure lbs. per square inch Date	
(9) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? Yes \(\sigma \) No If yes, by whom? Self	
	Work started 11-27 1967 Completed 11-28 1967
gal./min. with 1 2 11 fty drawdown after 1 hrs.	Date well drilling machine moved off of well 11-28 1967
	Drilling Machine Operator's Certification: This well was constructed under my direct supervision. Mate-
Bailer test gal./min. with ft. drawdown after hrs.	rials used and information reported above are true to my best
Artesian flow g.p.m. Date	knowledge and belief
Temperature of water Was a chemical analysis made? ☐ Yes ↓ No	[Signed] (Drilling Machine Operator) Date / 19.
(10) CONSTRUCTION:	1.70
Well seal—Material used Bentonite	Drilling Machine Operator's License No. 436
Depth of seal 18 ft.	Water Well Contractor's Certification:
Diameter of well bore to bottom of sealin.	This well was drilled under my jurisdiction and this report is
Were any loose strata cemented off? ☐ Yes ¾☐ No Depth	true to the best of my knowledge and belief.
Was a drive shoe used? ☑ Yes ☐ No	NAME Merle Warren Well Drilling (Person, firm or corporation) (Type or print)
Did any strata contain unusable water? Yes YNo	
Type of water? depth of strata	Address Rt. 1, Box 85, Tangent, Oregon
Method of sealing strata off	11/1/0 /1) arread
	[Signed] (Water Well Contractor)
Was well gravel packed? Yes Yoo Size of gravel:	Contractor's License No. 182 Date 1/28, 1967
Gravel placed from ft. to ft.	Contractor's License No. 182 Date