Mr Shelby

RECEIVED
OCT 1959
STATE ENGINEER
SALEM, OREGON

LINN
4642

10/3W-9B

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON

State Well No. .....

State Permit No. G1608

(1) OWNER:

Name N. V. AND NELLIE SHELBY

Address Rt. 2 Box 193
ALBANY, ORE.

(2) LOCATION OF WELL:

County LINN Owner's number, if any— 9

NW ¼ NE ¼ Section 9 T. 10S R. 3W W.M.

Bearing and distance from section or subdivision corner
S. 54° 30' E. 213 CHAINS FROM THE NW CORNER OF NE¼ OF S. 9, T. 10 S., R. 3 W.

(3) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☒

10" Diam. from -1 ft. to 26 ft. Gage 288
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? ☒ Yes ☐ No

Type of perforator used Slots

SIZE of perforations ½" in. by 8 in.

48 perforations from 20 ft. to 25 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed ☐ Yes ☐ No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? ☐ Yes ☐ No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? ☐ Yes ☐ No To what depth? ft.
Material used in seal—
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? Depth of strata 26'
Method of sealing strata off

(10) WATER LEVELS:

Static level 12 ft. below land surface Date 10-12-59
Artesian pressure lbs. per square inch Date

Log Accepted by:
[Signed] N. V. Shelby (Owner) Date 10-30, 1959
Nellie L. Shelby

(11) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom? Driller

Yield: 200 gal./min. with 2 ft. drawdown after 3 hrs.
" " " "
" " " "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water 54 Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG: Diameter of well 10 inches.

Depth drilled 26 ft. Depth of completed well 26 ft.

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Sandy Loam	top	13
Sand & Gravel	13	20
River "	20	26

Work started 10-11 1959 Completed 10-12 1959

(13) PUMP:

Manufacturer's Name PACIFIC

Type: 3" CENTRIFUGAL H.P. 20

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Hamilton Well Drilling Co. (Person, firm, or corporation) (Type or print)

Address 838 E 3rd Ave Albany

Driller's well number #2

[Signed] Bill Hamilton (Well Driller)

License No. 52 Date 10-12, 1959

(USE ADDITIONAL SHEETS IF NECESSARY)